

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 36646
 Permit No. 57223
 Basin 04-61

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in
 accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 17075

1. OWNER FARRICK GOLDSIRIKE ADDRESS AT WELL LOCATION GOLDSIRIKE MINE
 MAILING ADDRESS PO BOX 29
ELKO, NV. 89801

2. LOCATION SW 1/4 NE 1/4 Sec. 24 T. 36 N. 49 E. EUREKA County
 PERMIT NO. 55695-T Issued by Water Resources Parcel No. N/A Subdivision Name N/A

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other.....

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other.....

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
BROWN ROCK, CLAY		0	75	75
WHITE CLAY		75	95	20
BLACK ROCK, CLAY		95	180	75
BLACK ROCK, FRACT		180	260	80
BLACK ROCK, CLAY		260	305	45
BLACK ROCK, FRACT		305	570	265
BLACK ROCK, CLAY		570	610	40
BLACK ROCK		610	775	165
BLACK ROCK, CLAY		775	830	55
BLACK ROCK, HARD		830	1170	340
BLACK ROCK, WHITE CLAY		1170	1245	75
BLACK ROCK		1245	1270	25
BLACK ROCK, CLAY		1270	1335	65
BLACK ROCK, FRACT		1335	1375	40
BLACK ROCK, WHITE CLAY		1375	1395	20
BLACK ROCK		1395	1450	55
BLACK ROCK, WHITE CLAY		1450	1530	80
BLACK ROCK, FRACT CALSTT	X	1530	1610	80

8. WELL CONSTRUCTION
 Depth Drilled 1610 Feet Depth Cased 1606 Feet

HOLE DIAMETER (BIT SIZE)

From		To	
Inches	Feet	Inches	Feet
<u>40</u>	<u>0</u>	<u>50</u>	<u>0</u>
<u>29</u>	<u>50</u>	<u>1610</u>	<u>1606</u>

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>34</u>	<u>134.67</u>	<u>.375</u>	<u>0</u>	<u>50</u>
<u>20</u>	<u>78.60</u>	<u>.375</u>	<u>0</u>	<u>1606</u>

Perforations:
 Type perforation COVER
 Size perforation 1/8"

From 796 feet to 1596 feet
 From feet to feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Poured Cement Grout Concrete Grout

Gravel Packed: Yes No
 From 50 feet to 1610 feet

9. WATER LEVEL
 Static water level 316 feet below land surface
 Artesian flow N/A G.P.M. N/A P.S.I.
 Water temperature 121 °F Quality

Date started APRIL 11 1991
 Date completed MAY 21 1991

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name IANG EXPLORATORY DRILLING Contractor
 Address 2286 W. 1500 S., S.L.C., UT. 84104 Contractor

Nevada contractor's license number 0021976 issued by the State Contractor's Board
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1665

Signed Ames Titus
 By driller performing actual drilling on site or contractor
 Date JUNE 1, 1991