

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 17310

1. OWNER Joe Aigner ADDRESS AT WELL LOCATION 9250 U. S. 395 North
 MAILING ADDRESS 9250 U.S. 395 North Reno, Nv 89506

2. LOCATION SE 1/4 SE 1/4 Sec. 1 T. 20 N/S R. 18 E Washoe County Anderson Acres
 PERMIT NO. 81-031-52 - Anderson Acres Subdivision Name

Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other.....

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other.....

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Green sand and clay		101	105	4
D. G. & tan clay with broken rock - Rhyolite		105	176	71
T.D. 176 feet				
There is a 20 foot blank on bottom of perf to aid in developing.				

'91 JUL -9 09:56
 STATE ENGINEER'S OFFICE

8. WELL CONSTRUCTION
 Depth Drilled 176 Feet Depth Cased 164 Feet

HOLE DIAMETER (BIT SIZE)
 From 6 Inches To 101 Feet
 From 101 Feet To 176 Feet
 From _____ Inches To _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
5	9.66	.188	84	164

Perforations: Type perforation factory
 Size perforation 3/32 X 3 triple perf

From 124 feet to 144 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal Refer to original log Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 90 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

Date started 5/28/91, 19____
 Date completed 5/28/91, 19____

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Blew with air to clean and develop	15		1 1/2 hours
Dirty water			

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Aqua Drilling & Well Service, Inc Contractor
 Address 625 Spice Islands Dr Suite L
Sparks, Nv 89431 Contractor

Nevada contractor's license number 15291
 issued by the State Contractor's Board

Nevada driller's license number issued by the Division of Water Resources the on-site driller 1132

Signed Roger M. Thrall
 By driller performing actual drilling on site or contractor
 Date Roger M. Thrall 5/30/91