WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 36687
Permit No.
Basin 92A

NOTICE OF INTENT NO. 17309

1. OWNER Wm Bender / Wholey Construction
MAILING ADDRESS 10525 Red Rock Rd
Reno, Nv 89506

ADDRESS AT WELL LOCATION 11255 Cimarron
Lot 65

2. LOCATION NE ¼ SW ¼ Sec. 24 T. 21 N/S R. 18 E. Washoe County
PERMIT NO. (Issued by Water Resources) 86-203-10 (Parcel No.) — Silver Knolls Ranches Unit # 6A (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Hard pan - brown		0	37	37
Brown clay & sand		37	140	103
Brown clay with multi-colored sands medium coarse		140	185	45
D.G. sands - green quartz colored mixed with brown clay		185	276	91
T. D. 276 feet				

Date started 6/10/91, 19
Date completed 6/11/91, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20+		1

8. WELL CONSTRUCTION
Depth Drilled 276 Feet Depth Cased 261 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches		0 Feet	55 Feet
8 Inches		55 Feet	276 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	+ 1½	261

Perforations:
Type perforation factory
Size perforation 3/32 X 3
From 221 feet to 241 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 90 ft.
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 90 feet to 261 feet

9. WATER LEVEL
Static water level 155 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cold °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name (Contractor) Aqua Drilling & Well Service, Inc
Address (Contractor) 625 Spice Islands Dr Suite L
Sparks, Nv 89431
Nevada contractor's license number issued by the State Contractor's Board 15291
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1132
Signed Roger M. Thrall (By driller performing actual drilling on site or contractor)
Date Roger M. Thrall 6/14/91

STATE ENGINEER
'91 JUN 21 AM 10:52

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627