WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 36696
Permit No.
Basin 9-110 C

NOTICE OF INTENT NO. 13372

1. OWNER Hawthorne Army Ammunition Plant
MAILING ADDRESS P. O. Box 15
Hawthorne, Nevada 89415-0015

ADDRESS AT WELL LOCATION Hawthorne - WADF

2. LOCATION NW ¼ NW ¼ Sec. 32 T 8 N/S R 30 E Mineral County
PERMIT NO. M/O-428 (Issued by Water Resources) | Parcel No. N/A | Subdivision Name N/A

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [X] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. MW-3 LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Light Brown to Brown Silty Sand		0.0	7.5	7.5
Light Brown Sandy Clay		7.5	9.5	2.0
Green to Light Green Silt	Yes	9.5	23.5	14.0
Interbedded Light Green Silt and Clay	Yes	23.5	34.5	

Date started June 20, 19 91
Date completed June 20, 19 91

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 34.5 Feet Depth Cased 34.5 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
8.0 Inches		0.0 Feet	34.5 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2.0	0.5	Schedule 40	0.0	34.5

Perforations:
Type perforation Slotted
Size perforation 0.01 Inches
From 11.0 feet to 29.5 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 9.0 feet to 34.5 feet

9. WATER LEVEL
Static water level 14.5 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Pezonella Associates, Inc. (Contractor)
Address 520 Edison Way (Contractor)
Reno, Nevada 89502
Nevada contractor's license number issued by the State Contractor's Board C-4186
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-1629
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 7-15-91

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627