WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 36700
Permit No.
Basin 92 B

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 16467

1. OWNER Kirsch Ind
MAILING ADDRESS 309 N Prospect St. Sturgis MI 49091
ADDRESS AT WELL LOCATION Production & Resource Stead Nev

2. LOCATION SW ¼ SE ¼ Sec. 31 T. 21 N/S R. 19 E. Washoe County
PERMIT NO. M/0376 (Issued by Water Resources) 90-142-04 (Parcel No.) Silver Lake Ind. Park (Subdivision Name)

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE Monitoring
Domestic ☐ Irrigation ☐ Test ☒
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☐
Other ☒ Auger

6. LITHOLOGIC LOG MW#4B

Material	Water Strata	From	To	Thickness
Brown Silty Fine Sand		0	5	5
Yellow Brown Sandy Clay		5	8	3
Yellow Brown Silty Clay w/ Fine Sand		8	11	3
Brown Silty Clay & Yellow Brown Clayey Silt w/ Fine Sand		11	13	2
Silty Fine Sand		13	21	8
Fine to Coarse Sand w/ Gravel		21	26	5
Yellow Brown Sand		26	32	6
Gray Green Silt w/ Fine Sand		32	34	2

Date started 5/7, 1991
Date completed 5/8, 1991

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
	N/A		

BAILER TEST
G.P.M. N/A Draw down ..... feet ..... hours
G.P.M. Draw down ..... feet ..... hours
G.P.M. Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 8 inches Total depth 34 feet
..... inches
..... inches
Casing record PVC
Weight per foot N/A Thickness Sch 40

Diameter	From	To
2 inches	0 feet	34 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Neat Cement Grout
Depth of seal 7.5 7.5 to 27 Bentonite hole plug feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 27 feet to 34 feet

Perforations:
Type perforation Slotted
Size perforation 020
From 28.5 feet to 34 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 10.5 feet below land surface
Flow N/A G.P.M. N/A P.S.I.
Water temperature Cold °F Quality N/A

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name [signature] Contractor
Address 1635 Belford Rd. Reno Nev. 89509 Contractor
Nevada contractor's license number issued by the State Contractor's Board
Nevada contractor's driller's number issued by the Division of Water Resources
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1028
Signed [signature] By driller performing actual drilling on site or contractor
Date 6/3/91

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627