WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 36766
Permit
Basin 164A

NOTICE OF INTENT NO. 3308

1. OWNER Whiskey Pete's
MAILING ADDRESS P.O. Box 93718
Las Vegas, Nev. 89193

ADDRESS AT WELL LOCATION I-15 So. & stateline

2. LOCATION SW ¼ NE ¼ Sec. 9 T. 27 N/S R. 59 E. Clark County
PERMIT NO. Waiver #M02106 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
sand & gravel		0	12	12
calichi		12	14	2
sand & gravel		14	20	6
cemented sand & gravel		20	32	12
sand & boulders		32	67	35
sand & gravel		67	105	38
cemented sand & gravel		105	108	3
gray clay sand & gravel		108	130	22
cemented gravel		130	144	14
clay sand & gravel		144	190	46
sand & gravel	230	190	250	60

RECEIVED
MAR 24 1992
Div. of Water Resources
Branch Office 2-124 Las Vegas, NV

Date started 3-4, 1992
Date completed 3-4, 1992

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
15		

8. WELL CONSTRUCTION
Depth Drilled 250 Feet Depth Cased 250 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches	0 Feet	250 Feet	
Inches	Feet	Feet	
Inches	Feet	Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4 5/8"	10.79	.237	+1	250

Perforations:
Type perforation Factory Cut
Size perforation 3" x 1/8" x 6 per ft
From 185 feet to 225 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 175
Placement Method: ☐ Pumped ☒ Poured

Seal Type:
☐ Neat Cement
☐ Cement Grout
☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 175 feet to 250 feet

9. WATER LEVEL
Static water level 200 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cool °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Allen Drilling, Inc. (Contractor)
Address 4847 So. Valley View Blvd. (Contractor)
Las Vegas, Nev. 89103
Nevada contractor's license number issued by the State Contractor's Board 18917
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1661
Signed Donald L. Walk (By driller performing actual drilling on site or contractor)
Date 3-17-92

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627