WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 36707
Permit No.
Basin 164A

NOTICE OF INTENT NO. 3309

1. OWNER Whiskey pete's
MAILING ADDRESS P.O. Box 93718
Las Vegas, Nev. 89193

ADDRESS AT WELL LOCATION
I-15 So. & Stateline

2. LOCATION SW ¼ NE ¼ Sec. 9 T. 27 N/S R. 59 E. Clark County
PERMIT NO. Waiver #M02106 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Type II		0	12	12
cemented sand & gravel		12	20	8
sand & gravel		20	26	6
cemented sand & gravel		26	42	16
sand & gravel		42	52	10
sand		52	58	6
cemented sand & gravel		58	70	12
clay sand & gravel		70	130	60
partially cemented	140	130	149	19
cemented		149	160	11

RECEIVED
MAR 24 1992
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started 2-28, 1992
Date completed 3-4, 1992

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
15		

8. WELL CONSTRUCTION
Depth Drilled 160 Feet Depth Cased 160 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 Inches	0 Feet	160 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4 5/8"	10.79	.237	+1	160

Perforations:
Type perforation Factory Cut
Size perforation 3" x 1/8" x 6 per ft
From 120 feet to 150 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 110
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 110 feet to 160 feet

9. WATER LEVEL
Static water level 135 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cool °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Allen Drilling, Inc. (Contractor)
Address 4847 So. Valley View Blvd. (Contractor)
Las Vegas, Nev. 89103
Nevada contractor's license number issued by the State Contractor's Board 18917
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1661
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 3-17-92

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627