WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

OFFICE USE ONLY
Log No. 36727
Permit No.
Basin 8-105

NOTICE OF INTENT NO. 14620

1. OWNER Don Leverty Construction
MAILING ADDRESS 207 Catherine park Dr. Glendora, Ca. 91740
ADDRESS AT WELL LOCATION (Brown) 1112 Oro Way. Gardnerville, Nev 89410

2. LOCATION SE ¼ NE ¼ Sec. 17 T. 12 N/S R. 20 E/E Douglas County
PERMIT NO. (Issued by Water Resources) 27-092-09 (Parcel No.) Terra Linda Est. (Subdivision Name)

3. TYPE OF WORK
New Well [X] Recondition [ ]
Deepen [ ] Other [ ]

4. PROPOSED USE
Domestic [X] Irrigation [ ] Test [ ]
Municipal [ ] Industrial [ ] Stock [ ]

5. TYPE WELL
Cable [ ] Rotary [X]
Other [ ]

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Gravel		0	22	22
Clay		22	25	3
Gravel, Some Clay		25	43	18
Conglomerate		43	103	60
Gravel	X	103	121	18
Conglomerate		121	130	9

'91 OCT 16 A11:03
RECEIVED
STATE ENGINEERS OFFICE

Date started 6-25, 19 91
Date completed 6-27, 19 91

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Airlift	20	N/A	N/A

BAILER TEST
G.P.M. N/A Draw down ____ feet ____ hours
G.P.M. ____ Draw down ____ feet ____ hours
G.P.M. ____ Draw down ____ feet ____ hours

8. WELL CONSTRUCTION
Diameter 12¼"0-130' inches Total depth 130' feet
____ inches
____ inches
Casing record 8 5/8" 0'-130'
Weight per foot ____ Thickness .188"

Diameter	From	To
8 5/8" inches	0 feet	130 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes [X] No [ ] Type Concrete
Depth of seal 50' feet
Gravel packed: Yes [X] No [ ]
Gravel packed from 50 feet to 130 feet

Perforations:
Type perforation Factory Slotted
Size perforation 3/32" X 3"
From 125 feet to 130 feet
From 95 feet to 105 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

9. WATER LEVEL
Static water level 42 feet below land surface
Flow N/A G.P.M. N/A P.S.I.
Water temperature Cold °F Quality Not Known

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Pre-Cambrian Drilling Co., Inc. (Contractor)
Address 794 Foothill, Rd. Gardnervillle, (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 0030267
Nevada contractor's driller's number issued by the Division of Water Resources 1652
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1652
Signed July 7 1991 (By driller performing actual drilling on site or contractor)
Date

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 10-83) (O)-627