

OFFICE USE ONLY
 Log No. 36729
 Permit No. _____
 Basin _____

WELL DRILLER'S REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 16415

1. OWNER Construction Zone ADDRESS AT WELL LOCATION 1820 Sullivan DR. Gardnerville, NV 89410
 MAILING ADDRESS PO Box 5098 Stateline Nv. 89449

2. LOCATION NW 1/4 SW 1/4 Sec. 24 T. 12 N. S. R. 20 E. Douglas County
 PERMIT NO. 29-490-04 Parcel No. Rohrstroth Subdivision Name

3. TYPE OF WORK
 New Well Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock Other

5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Cobbles</u>		<u>0</u>	<u>75</u>	<u>75</u>
<u>cobbles, clay strks</u>		<u>75</u>	<u>195</u>	<u>120</u>
<u>Gravel</u>	<u>X</u>	<u>195</u>	<u>215</u>	<u>20</u>
<u>CLAY</u>		<u>215</u>	<u>235</u>	<u>20</u>
<u>Gravel, sand, clay</u>	<u>X</u>	<u>235</u>	<u>253</u>	<u>18</u>
<u>CLAY</u>		<u>253</u>	<u>255</u>	<u>3</u>

'91 MAY -9 110:36
 STATE ENGINEER'S OFFICE

8. WELL CONSTRUCTION
 Diameter 10 inches Total depth 255 feet
 _____ inches
 _____ inches

Casing record _____
 Weight per foot _____ Thickness 1.88

Diameter	From	To
<u>6</u> inches	<u>1</u> feet	<u>255</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes No Type Cement
 Depth of seal 50 feet
 Gravel packed: Yes No
 Gravel packed from 50 feet to 255 feet

Perforations:
 Type perforation FACTORY SLOT
 Size perforation 3/32" x 3"
 From 195 feet to 215 feet
 From 235 feet to 255 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Date started 4-30 1991
 Date completed 5-2 1991

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
_____	_____	_____	_____
_____	_____	_____	_____

BAILER TEST

G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours

9. WATER LEVEL
 Static water level 1.60 feet below land surface
 Flow 0 G.P.M. 10 PSI
 Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Energy Exploration Drilling Contractor
 Address PO Box 1538 Minden, NV 89423 Contractor
 Nevada contractor's license number 21491 issued by the State Contractor's Board
 Nevada contractor's driller's number 1407 issued by the Division of Water Resources
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1407
 Signed John Woods By driller performing actual drilling on site or contractor
 Date 5-3-91