

WELL DRILLER'S REPORT

Please complete this form in its entirety

NOTICE OF INTENT NO. 16768

PRINT OR TYPE ONLY

1. OWNER Dan Phillips ADDRESS AT WELL LOCATION 1368 Calle
Peng Veno Str. Caraville NV 89410
 MAILING ADDRESS 796-A Wagon Dr
Garderville NV, 89410
 2. LOCATION NW 1/4 NW 1/4 Sec. 5 T. 12 N/S R. 21 E. Douglas County
 PERMIT NO. N/A Issued by Water Resources Parcel No. 35-130-16 Submission Name Fish Springs

| | | |
|---|--|---|
| 3. TYPE OF WORK | 4. PROPOSED USE | 5. TYPE WELL |
| New Well <input checked="" type="checkbox"/> Recondition <input type="checkbox"/> | Domestic <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Test <input type="checkbox"/> | Cable <input type="checkbox"/> Rotary <input checked="" type="checkbox"/> |
| Deepen <input type="checkbox"/> Other <input type="checkbox"/> | Municipal <input type="checkbox"/> Industrial <input type="checkbox"/> Stock <input type="checkbox"/> | Other <input type="checkbox"/> |

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thick-ness |
|---------------------|--------------|------------|-------------|------------|
| <u>Over Burden</u> | | <u>0</u> | <u>10'</u> | <u>10</u> |
| <u>Comd GRAVEL</u> | | <u>10'</u> | <u>70'</u> | <u>60</u> |
| <u>Loose GRAVEL</u> | | <u>70</u> | <u>82'</u> | <u>12</u> |
| <u>HARD ROCK</u> | | <u>82'</u> | <u>125'</u> | <u>43</u> |
| <u>CLAY</u> | | <u>125</u> | <u>130</u> | <u>5</u> |
| <u>GRAVEL</u> | <u>yes</u> | <u>120</u> | <u>143</u> | <u>13</u> |
| <u>HARD ROCK</u> | | <u>143</u> | <u>150</u> | <u>7</u> |

JUN 13 AM 10:36
 STATE ENGINEERS OF NV

8. WELL CONSTRUCTION 150'

Diameter 10 inches Total depth 150' feet

Casing record Steel

Weight per foot 14 lbs Thickness 188

| Diameter | From | To |
|---------------------|----------------|------------------|
| <u>6 1/2</u> inches | <u>+2</u> feet | <u>150'</u> feet |
| _____ inches | _____ feet | _____ feet |
| _____ inches | _____ feet | _____ feet |
| _____ inches | _____ feet | _____ feet |
| _____ inches | _____ feet | _____ feet |
| _____ inches | _____ feet | _____ feet |

Surface seal: Yes No Type Neat cement Pumped

Depth of seal 50' feet

Gravel packed: Yes No

Gravel packed from 50 feet to 150 feet

Perforations:

Type perforation mill slot

Size perforation 3x 3/32

From 130' feet to 150' feet

From _____ feet to _____ feet

Date started 5-22- 1991
 Date completed 5-27- 1991

7. WELL TEST DATA

| Pump RPM | G.P.M. | Draw Down | After Hours Pump |
|-----------------|----------------|-----------|------------------|
| <u>Blow/Air</u> | <u>50+ gpm</u> | | <u>6 Hrs</u> |
| _____ | _____ | _____ | _____ |
| _____ | _____ | _____ | _____ |

BAILER TEST

| G.P.M. | Draw down | feet | hours |
|--------|-----------|-------|-------|
| _____ | _____ | _____ | _____ |
| _____ | _____ | _____ | _____ |
| _____ | _____ | _____ | _____ |

9. WATER LEVEL

Static water level 27' feet below land surface

Flow 50+ G.P.M. P.S.I. _____

Water temperature cool °F Quality N/A

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name KRACHACK Drilling Contractor

Address 2886 Fuller Dr. Minden NV Contractor 89423

Nevada contractor's license number issued by the State Contractor's Board 021268

Nevada contractor's driller's number issued by the Division of Water Resources 1380

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1544

Signed Maurin T. Hach By driller performing actual drilling on site or contractor

Date 5-28-91