

OFFICE USE ONLY
 Log No. 36739
 Permit No. _____
 Basin _____
 36629

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 36629

1. OWNER Buckeye Creek Inc. ADDRESS AT WELL LOCATION 1628 East Valley Rd.
 MAILING ADDRESS Minden NV 89423

2. LOCATION N1/4 SW 1/4 Sec. 26 T. 13 N. R. 20 E Douglas County
 PERMIT NO. NA Issued by Water Resources Parcel No. 23-295-38 Subdivision Name Buckeye Creek

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thick-ness |
|---|-------------------------------------|------------|------------|------------|
| <u>Sandy clay with interbedded cobbles</u> | | <u>0</u> | <u>46</u> | <u>46</u> |
| <u>clay with some interbedded sand & gravel</u> | | <u>46</u> | <u>156</u> | <u>110</u> |
| <u>SAND & gravel</u> | <input checked="" type="checkbox"/> | <u>156</u> | <u>163</u> | <u>7</u> |
| <u>Clay with sand & gravel interbedded</u> | | <u>163</u> | <u>178</u> | <u>15</u> |
| <u>SAND & gravel</u> | <input checked="" type="checkbox"/> | <u>178</u> | <u>189</u> | <u>11</u> |
| <u>Clay with interbedded sand & gravel</u> | | <u>189</u> | <u>194</u> | <u>5</u> |
| <u>SAND & gravel</u> | <input checked="" type="checkbox"/> | <u>194</u> | <u>206</u> | <u>12</u> |

8. WELL CONSTRUCTION
 Depth Drilled 206 Feet Depth Cased 206 Feet

HOLE DIAMETER (BIT SIZE)
 From 12 Inches To 206 Feet
 _____ Inches _____ Feet
 _____ Inches _____ Feet

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|--------------------|---------------------|-------------------------|-------------|------------|
| <u>6.75</u> | | <u>.188</u> | <u>1</u> | <u>206</u> |

Perforations:
 Type perforation mill cuts
 Size perforation 2 1/2
 From 160 feet to 206 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 100' Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 100 feet to 206 feet

9. WATER LEVEL
 Static water level 57 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature 60.0 °F Quality UNKNOWN

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name DRS'S DRILLING INC. Contractor
 Address P.O. Box 21421 Contractor
CARSON CITY NV. 89024
 Nevada contractor's license number issued by the State Contractor's Board 0023129
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1386
 Signed T. Hanson
 By driller performing actual drilling on site or contractor
 Date 7-16-91

Date started June 10 1991
 Date completed June 12 1991

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

| | G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|-----------------|-----------|-------------------------------|--------------|
| <u>Estimate</u> | <u>50</u> | <u>from 190</u> | <u>2</u> |