WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 36739
Permit No.
Basin

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 14622

1. OWNER John Burgman
MAILING ADDRESS 1536 Saltbrush Ct. Gardnerville, Nev. 89410
ADDRESS AT WELL LOCATION 1536 Saltbrush, Gardnerville, Nev. 89410

2. LOCATION SE ¼ NW ¼ Sec. 36 T. 13N N/S R. 20E E. Douglas County
PERMIT NO. (Issued by Water Resources) 23-472-28 (Parcel No.) Wildflower Ridge (Subdivision Name)

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Gravel		0	22	22
Clay, Sandy		22	28	6
Gravel & Clay		28	91	63
Clay, Sticky		91	136	45
Gravel		136	168	32
Clay		168	187	19
Gravel	X	187	224	37
Clay, Sand Streaks		224	269	45
Gravel		269	304	35
Clay		304	311	7
Gravel	X	311	348	37
Clay		348	361	13
Gravel	X	361	420	59

Date started 5-28, 19 91
Date completed 6-7, 19 91

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Airlift	25		

BAILER TEST
G.P.M. N/A Draw down feet hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter 12¼" 0-50' inches Total depth 420 feet
8 3/4" 50-420' inches
inches
Casing record 6 5/8" O.D. 0-420'
Weight per foot 13 Thickness 0.188

Diameter	From	To
6 5/8" inches	0 feet	420 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Concrete
Depth of seal 50' feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50 feet to 420 feet

Perforations:
Type perforation Factory Slotted
Size perforation 3/32" X 3"
From 220 feet to 230 feet
From 270 feet to 280 feet
From 300 feet to 310 feet
From 330 feet to 340 feet
From 360 feet to 370 feet
~~390~~ ~~400~~

9. WATER LEVEL
Static water level 218 feet below land surface
Flow N/A G.P.M. N/A P.S.I.
Water temperature Cold °F Quality Not Known

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Pre-Cambrian Drilling Co., Inc. (Contractor)
Address 794 Foothill Rd. Gardnerville, Nv. (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 0030267
Nevada contractor's driller's number issued by the Division of Water Resources 1652
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1652
Signed (By driller performing actual drilling on site or contractor)
Date ~~MAY~~ June 11, 1991

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O) 627