

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
Please complete this form in its entirety in accordance with NRS 534.370 and NAC 534.340

NOTICE OF INTENT NO. 16767

1. OWNER Phil Fingar ADDRESS AT WELL LOCATION N-A
MAILING ADDRESS P.O. Box 644, Gardnerville NV 89410

2. LOCATION SE 1/4 NW 1/4 Sec. 33 T. 13 N. 8 R. 21 E. Douglas County
PERMIT NO. N-A 23-430-06 fish springs Area Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary
 Other _____

6. LITHOLOGIC LAB

| Material | Water Strata | From | To | Thickness |
|-----------------------|--------------|------|------|-----------|
| Over Burden | | 0' | 2' | 2' |
| Cobbles Stones | | 2' | 15' | 13' |
| CLAY | | 15' | 35' | 20' |
| Gravel & clay strings | | 35' | 85' | 50' |
| Hard Rock | | 85' | 97' | 12' |
| Gravel | | 97' | 113' | 16' |
| CLAY | | 113' | 120' | 7' |
| Gravel | | 120' | 129' | 7' |
| Hard Rock Fractures | | 129' | 152' | 23' |

8. WELL CONSTRUCTION
Total Depth 152' Feet

HOLE DIAMETER (BIT SIZE)
From 10 Inches 0 Feet 152' Feet
Inches _____ Feet _____ Feet
Inches _____ Feet _____ Feet

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|--------------------|---------------------|-------------------------|-------------|-------------|
| <u>6 5/8</u> | <u>14</u> | <u>188</u> | <u>110'</u> | <u>152'</u> |

Surface Seal: Yes No Seal Type:
Depth of Seal 50' Neat Cement
Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
From 50' Feet to 152' Feet

9. WATER LEVEL
Static water level 50' feet below land surface
Artesian flow N/O G.P.M. 30+ P.S.I.
Water temperature cool °F Quality _____

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Kawchack Drilling Contractor
Address 2668 Fuller Minden NV 89423 Contractor

Date started May 17 1991
Date completed May 20 1991

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

| | G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---------------------------|--------|-------------------------------|-------------------|
| <u>Blow/Air</u> | | | <u>5 1/2 Hrs.</u> |
| <u>Well makes 30+ gal</u> | | | |

Nevada contractor's license number issued by the State Contractor's Board #021268
Nevada contractor's driller's number issued by the Division of Water Resources 1380
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1544
Signed Martin T. Mack
By driller performing actual drilling on site or contractor
Date 5-21-91