

WELL DRILLER'S REPORT

Please complete this form in its entirety

NOTICE OF INTENT NO. 17229

PRINT OR TYPE ONLY

1. OWNER MR. + MRS. BOB MOCCIO ADDRESS AT WELL LOCATION 2908 ROMERO,
GARDNERVILLE, NV JOHNSON LANE AREA

2. LOCATION NE 1/4 SW 1/4 Sec. 26 T. 14 N. R. 20 E DOUGLAS County
 PERMIT NO. 21-230-13 JOHNSON LANE Subdivision Name

3. TYPE OF WORK	4. PROPOSED USE	5. TYPE WELL
New Well <input checked="" type="checkbox"/> Recondition <input type="checkbox"/>	Domestic <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Test <input type="checkbox"/>	Cable <input type="checkbox"/> Rotary <input checked="" type="checkbox"/>
Deepen <input type="checkbox"/> Other <input type="checkbox"/>	Municipal <input type="checkbox"/> Industrial <input type="checkbox"/> Stock <input type="checkbox"/>	Other <input type="checkbox"/>

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SANDY CLAY		0'	170'	170'
GRAVEL, COARSE SAND		170'	190'	20'
SANDY CLAY		190'	196'	6'
BASALT, FRACTURED		196'	221'	25'
CLAY, w/SAND + GRAVEL		221'	255'	34'
BASALT + CLAY LAYERS		255'	275'	20'
BASALT + CLAY LAYERS	✓	275'	300'	25' +

91 JUN 13 10:36 AM
 STATE ENGINEERS CIVIL

8. WELL CONSTRUCTION

Diameter 10 5/8 inches Total depth 300 feet
6 1/8 inches

Casing record 6 5/8" x 220', 5 9/16" x 80', STEEL
 Weight per foot 17 #, 14 # Thickness .188"

Diameter	From	To
<u>6 5/8</u> inches	<u>0</u> feet	<u>220</u> feet
<u>5 9/16</u> inches	<u>220</u> feet	<u>300</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes No Type CEMENT GROUT
 Depth of seal 50 feet
 Gravel packed: Yes No
 Gravel packed from 50 feet to 220 feet

Perforations:
 Type perforation FACTORY, SINGLE
 Size perforation 3/32" x 3"
 From 200 feet to 220 feet
 From 280 feet to 300 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Date started MAY 29, 1991
 Date completed JUNE 6, 1991

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
<u>AIR TEST</u>	<u>12 +</u>		

BAILER TEST

G.P.M.	Draw down	feet	hours

9. WATER LEVEL

Static water level 215 feet below land surface
 Flow _____ G.P.M. _____ P.S.I.
 Water temperature COLD °F Quality UNKNOWN

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name EDDCO EXPLORATION, INC. Contractor
 Address 7780 CURRY RD., FALLON, NV Contractor
 Nevada contractor's license number issued by the State Contractor's Board 27673
 Nevada contractor's driller's number issued by the Division of Water Resources 1586
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1726
 Signed Pat F. Moccio By driller performing actual drilling on site or contractor
 Date 6-6-91