

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT  
 Please complete this form in its entirety in  
 accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 10/22

1. OWNER George Reynolds ADDRESS AT WELL LOCATION South Trust Ranch  
 MAILING ADDRESS P.O. Box 18 Round Mt. Nevada 89045  
 2. LOCATION N 20 1/4 S 1/4 W 1/4 Sec. 10 T. 14 N N/S R. 43 E County Nye  
 PERMIT NO. 56622 3-811-01 Guelich Area Nye Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Topsoil		0'	20'	20'
Sand + Gravels		20'	128'	108'
Sand + Clays		128'	160'	32'
Gravels		160'	185'	25'
Clays		185'	205'	20'
Gravels		205'	240'	35'

8. WELL CONSTRUCTION  
 Depth Drilled 240 Feet Depth Cased 240 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 9 3/8 Inches To 0 Feet 240 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 1/2</u>		<u>1/4"</u>	<u>0'</u>	<u>240</u>

Perforations:  
 Type perforation Slot  
 Size perforation 1/8" by 2"  
 From 160 feet to 180 feet  
 From 200 feet to 240 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50'  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 50 feet to 240 feet

9. WATER LEVEL  
 Static water level 6' feet below land surface  
 Artesian flow N/A G.P.M. \_\_\_\_\_ P.S.I. \_\_\_\_\_  
 Water temperature 40 °F Quality Good

Date started 4-11, 1991  
 Date completed 4-14, 1991

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>75</u>		<u>4 hrs</u>

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Bruce Young Contractor  
 Address Box 30M Goldpoint Contractor  
Goldfield Nevada  
 Nevada contractor's license number issued by the State Contractor's Board \_\_\_\_\_  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 871  
 Signed Bruce Young  
 By driller performing actual drilling on site or contractor  
 Date 6-28-91