

OFFICE USE ONLY
 Log No. 30762
 Permit No. _____
 Basin 9-107 5P

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 17540

1. OWNER Robert E. + Adrienne Antovelli ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 267 Art. 51A, Wellington, NV _____
 2. LOCATION NW 1/4 NW 1/4 Sec 28 T 12 N R 23 E LYON County
 PERMIT NO. 09-011-17 Issued by Water Resources Parcel No. 20 Phail/ALNO9-01-07 Subdivision Name Foot Hill Estate

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top Soil	NO	1	3	3
Bolder's	NO	3	80	77
D G	NO	80	140	60
gravel	yes	140	180	40

91 MAY 22 AM 11:08
 RECEIVED
 STATE ENGINEERS OF NV

8. WELL CONSTRUCTION
 Depth Drilled 180 Feet Depth Cased 180 Feet

HOLE DIAMETER (BIT SIZE)
 From To
12 3/4 Inches 0 Feet 180 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8 3/4</u>	—	<u>188</u>	<u>0</u>	<u>180</u>

Perforations:
 Type perforation Factory
 Size perforation 5/32
 From 140 feet to 180 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 50 feet to 180 feet

9. WATER LEVEL
 Static water level 9.5 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cool °F Quality good

Date started May 3, 1991
 Date completed May 5, 1991

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>50+</u>		<u>3 HR</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Enduro Drilling Contractor
 Address PO 92 Smith, NV Contractor
 Nevada contractor's license number issued by the State Contractor's Board 32166
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1751
 Signed James D. Conner
 By driller performing actual drilling on site or contractor
 Date May 8 1991