WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 36767
Permit No.
Basin 9-110 C

NOTICE OF INTENT NO. 13372

1. OWNER Hawthorne Army Ammunition Plant
MAILING ADDRESS P. O. Box 15, Hawthorne, Nevada 89415-0015
ADDRESS AT WELL LOCATION Hawthorne - WADF

2. LOCATION NW ¼ NW ¼ Sec. 32 T. 8 N/S R. 30 E. Mineral County
PERMIT NO. M/O-428 (Issued by Water Resources) | N/A (Parcel No.) | N/A (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [X] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [XX] Rotary [ ] RVC
[ ] Air [ ] Other

6. MW-2 LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Light Brown to Brown Silty Sand		0.0	12.5	12.5
Light Brown to Yellow Brown Sand	Yes	12.5	19.5	7.0
Light Green Clay	Yes	19.5	28.0	8.5
Interbedded Light Green Clay and Silt	Yes	28.0	35.0	

Date started June 19, 1991
Date completed June 19, 1991

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 35.0 Feet Depth Cased 35.0 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
8.0 Inches	0.0 Feet	35.0 Feet	
Inches	Feet	Feet	
Inches	Feet	Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2.0	0.5	Schedule 40	0.0	35.0

Perforations:
Type perforation Slotted
Size perforation 0.01 Inches
From 12.5 feet to 30.0 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 8.5
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [XX] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 10.5 feet to 35.0 feet

9. WATER LEVEL
Static water level 15.0 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Pezonella Associates, Inc. (Contractor)
Address 520 Edison Way, Reno, Nevada 89502 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board C-4186
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-1629
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 7-15-91

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627