WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLERS REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

OFFICE USE ONLY
Log No. 36778
Permit No.
Basin 69

NOTICE OF INTENT NO. 16030

1. OWNER Harold Lipska
MAILING ADDRESS H.C.R. 2420
Wnmca., Nevada 89445

ADDRESS AT WELL LOCATION 6990 Mountain View

2. LOCATION S.W. ¼ S.W. ¼ Sec. 1 T. 39 N. N/S R. 38 E. Humboldt County
PERMIT NO. (Issued by Water Resources) 06-095-13 (Parcel No.) Lot #13 Paradise Valley Estates Unit #1 (Subdivision Name)

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☒ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Soil brown | | 0 | 2 | 2 |
| Clay brown | | 2 | 18 | 16 |
| Gravely clay brown | | 18 | 46 | 28 |
| Sandy clay brown | | 46 | 93 | 47 |
| Course sand & gravel brown. | 32 | 93 | 125 | 32 |

91 JUN 12 A10:31 STATE ENGINEER

Date started May 15, 1991
Date completed May 16, 1991

7. WELL TEST DATA

| Pump RPM | G.P.M. | Draw Down | After Hours Pump |
|---|---|---|---|
| | | | |

BAILER TEST
G.P.M. 36 Draw down 5 feet 2½ hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 0 inches Total depth 125 feet
Casing record 10" TO 50'
Weight per foot 14 lbs. Thickness .188

| Diameter | From | To |
|---|---|---|
| 6 inches | 0 feet | 125 feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |

Surface seal: Yes ☒ No ☐ Type cement
Depth of seal 50 feet
Gravel packed: Yes ☐ No ☒
Gravel packed from feet to feet

Perforations:
Type perforation torch
Size perforation 1/8" by 5"
From 95 feet to 125 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 57 feet below land surface
Flow good G.P.M. P.S.I.
Water temperature 54 °F. Quality good

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name T. R. Drilling (Contractor)
Address P.O. Box 1982 Wnmca., Nv. 89445 (Contractor)
Nevada contractor's license number 017721
Nevada contractor's drillers number 1190
Nevada driller's license number 1190
Signed Thomas (Actual Driller) (Contractor)
Date June 1, 1991

(Rev. 6-81) USE ADDITIONAL SHEETS IF NECESSARY O-627 CR434