

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

**WELL DRILLER'S REPORT**  
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 5930

1. OWNER Jerry Foster ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS P. O. Box 146 South Valley Road, Orovada, Nv.  
Orovada, NV 89425

2. LOCATION NW 1/4 NE 1/4 Sec. 5 T. 41N N/S R. 37 E Humboldt County  
 PERMIT NO. \_\_\_\_\_ (None) Lot 6 - None - Block (None)  
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	3	3'
Fine to Medium Sand		3	9	6'
Clay/Sand Mix		9	15	6'
Fine Sand		15	18	3'
Sand/Clay Mix		18	27	9'
Green Clay		27	31	4'
Fine Sand		31	39	8'
Fine/Med. Sand		39	42	3'
Clay/Sand Mix		42	45	3'
Fine Sand		45	50	5'
Green Clay		50	54	4'
Fine/crse. sand		54	60	6'
Crse. Sand/Some Rock		60	69	9'
Flat Shale Rock/Sand		69	71	2'
Med. Sand		71	75	4'
Green Clay		75	80	5'
Crse. Sand		80	85	5'
Crse. Sand & Gravel		85	90	5'
Sand & Gravel		90	93	3'
Crse. Sand		93	110	17'

8. WELL CONSTRUCTION  
 Depth Drilled 110 Feet Depth Cased 110 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From	To
10	0	50
6	50	110

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 1/2"	17.02	.250	50	110
10"	19.70	.188	0	50

Perforations xxxxxxx Screens -5 1/2" - 5'/.020

Type perforation \_\_\_\_\_  
 Size perforation \_\_\_\_\_  
 From 105 feet to 110 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout

Depth of Seal 50'

Placement Method:  Pumped  Poured

Gravel Packed:  Yes  No  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

9. WATER LEVEL  
 Static water level 38' feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cold °F Quality Good

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name PETE COPE DRILLING CO., INC.  
6505 W. Chandler Blvd.  
 Address Meridian, ID 83642  
Contractor

Nevada contractor's license number 13443  
 issued by the State Contractor's Board

Nevada driller's license number issued by the 1456  
 Division of Water Resources, the on-site driller

Signed PETE COPE DRILLING CO., INC.  
 BY: [Signature]  
By Driller performing actual drilling on site or contractor

Date June 15, 1991

Date started May 12, 19 91  
 Date completed May 16, 19 91

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

STATE ENGINEER'S SUPPLEMENTAL STAMP  
 JUN 26 1991  
 14741