WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 36843
Permit No.
Basin 102

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 16607

1. OWNER Woodrow W. & Roberta E. Cave
MAILING ADDRESS 508 N. Curry St. Carson City Nev. 89703
ADDRESS AT WELL LOCATION 5460 White Oak DR. Silver Springs Nev.

2. LOCATION SE ¼ NW ¼ Sec. 1 T. 17 N/S R. 24 E. Lyon County
PERMIT NO. (Issued by Water Resources) Lot #20 (Parcel No.) Mountain View (Subdivision Name) APN # 17-022-13

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
TopSoil		0	4	4
Coarse Sand		4	6	2
Brown Clay		6	20	14
Coarse Sand		20	22	2
Brown Clay		22	31	9
Brown Clay + Gravel		31	32	1
Black Rock (Fractured)		32	73	41
Brown Rock (Fractured)		73	81	8
Brown Rock (Fractured) with Clay		81	89	8
Brown Clay, Gravel, Rock		89	98	9
Brown Rock (Fractured) with Clay		98	102	4
Brown Clay-Gravel		102	110	8
Blackish Clay-Gravel		110	112	2
Blackish & Brown Rock (Fractured)	X	112	120	8
Blackish Rock & Clay		120	123	3
Blackish Rock (Fractured)		123	135	12
Blackish Rock (Loose)	X	135	159	24

Date started 5-20, 1991
Date completed 5-29, 1991

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. 27 Draw down 17 feet ½ hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter 11" inches Total depth 160 feet
inches
inches
Casing record .188
Weight per foot Thickness .188

Diameter	From	To
6 5/8 inches	41 feet	159 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type Cement
Depth of seal 50 feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 50 feet to 159 feet

Perforations:
Type perforation Sawed
Size perforation 3/32 x 3" 6 Rows
From 139 feet to 159 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 86 feet below land surface
Flow G.P.M. P.S.I.
Water temperature cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Ogden BROS DRILLING (Contractor)
Address 162 N Bybee Lane (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 15646
Nevada contractor's driller's number issued by the Division of Water Resources 634
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 634
Signed Larry Ogden (By driller performing actual drilling on site or contractor)
Date 6-25-91

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627