WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 36845
Permit No.
Basin 102

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 18517

1. OWNER Raymond OTT
MAILING ADDRESS 235 Sharpe Ave
Campbell Calif 95008

ADDRESS AT WELL LOCATION 1860 E. 10 St
ST 89429
PARCEL # 17-431-10

2. LOCATION NE ¼ NE ¼ Sec. 19 T. 17 N R. 25 E. Lyon County
PERMIT NO. (Issued by Water Resources) Lot 10 (Parcel No.) Lahontan Sub #5 (Subdivision Name)

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Top Soil Sandy | | 0 | 5 | 5 |
| Sand + Clay | | 5 | 32 | 27 |
| Coarse Sand-Blackish | | 32 | 58 | 26 |
| Coarse Sand-Greenish | | 58 | 70 | 12 |
| Gray-Green Clay | | 70 | 85 | 15 |
| Gray-Green Fine Sand | | 85 | 93 | 8 |
| Gray-Green Clay | | 93 | 96 | 3 |
| Gray-Green Fine Sand | | 96 | 100 | 4 |
| Gray-Green Coarse Sand | | 100 | 110 | 10 |
| Gray-Green Clay | | 110 | 115 | 5 |
| Gray-Green Coarse Sand | | 115 | 120 | 5 |
| Coarse Sand-Brown | | 120 | 124 | 4 |
| Coarse Sand + Gravel Brown | X | 124 | 144'3" | 20'3" |

Date started 5-16-, 19 91
Date completed 5-20, 19 91

7. WELL TEST DATA

| Pump RPM | G.P.M. | Draw Down | After Hours Pump |
|---|---|---|---|
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |

BAILER TEST
G.P.M. 40 Draw down 7 feet ½ hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION 145
Diameter 13" inches Total depth 144'3" feet
inches
inches
Casing record .188
Weight per foot Thickness .188

| Diameter | From | To |
|---|---|---|
| 8 5/8 inches | +1 feet | 144'3" feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |

Surface seal: Yes ☑ No ☐ Type Cement
Depth of seal 50' feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 50 feet to 144'3" feet

Perforations:
Type perforation Sawed
Size perforation 3/32 x 3" x 8 Rows
From 124'3" feet to 144'3" feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 33 feet below land surface
Flow G.P.M. P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Ogden Bros Drilling (Contractor)
Address 162 N Bybee Lane (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 15646
Nevada contractor's driller's number issued by the Division of Water Resources 634
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 634
Signed Gary Ogden (By driller performing actual drilling on site or contractor)
Date 7-8-91

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627