

OFFICE USE ONLY
 Log No. 36851
 Permit No. _____
 Basin 8-103
 NOTICE OF INTENT NO. 17306

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER William Knapp ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS P. O. Box 6 Columbia So Extension
Silver City, Nv 89428 off Route 341
 2. LOCATION NE 1/4 NE 1/4 Sec. 29 T. 16 N/S R. 21 E Lyon County _____
 PERMIT NO. 16-171-04 Subdivision Name _____
 Issued by Water Resources Parcel No. _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Overburden		0	1	1
Ryolite some brown clay		1	14	13
Ryolite multi-colored		14	176	162
Brown rock specked with white & yellow		176	202	26
Yellow rock with bluish specks		202	212	10
Purple rock with white specks		212	242	30
Multi-colored rock yellow gray brown quartz		242	280	38
Multi-colored rock mixed with whiteish gray clay		280	299	19
T.D. 299 ft				

8. WELL CONSTRUCTION
 Depth Drilled 299 Feet Depth Cased 299 Feet
 HOLE DIAMETER (BIT SIZE)

Inches	From	To	Feet	Feet
10	0	55		
8 1/2	55	299		

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8"	12.92	.188	+1 1/2	299

Perforations:
 Type perforation factory
 Size perforation 3/32 X 3
 From 259 feet to 279 feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 299 feet

9. WATER LEVEL
 Static water level 200 feet below land surface
 Artesian flow X NO G.P.M. _____ P.S.I. _____
 Water temperature 60.1 °F Quality Brown

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Aqua Drilling & Well Service, Inc
 Address 625 Spice Islands Dr Suite L
Sparks, Nv 89431
 Nevada contractor's license number issued by the State Contractor's Board 15291
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1132
 Signed Roger M. Thrall
 By driller performing actual drilling on site or contractor
 Date 5/16/91

Date started 5/14/91, 19____
 Date completed 5/15/91, 19____

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift			
<u>blew with air to clean and develop.</u>			
	<u>2</u>		<u>4-</u>