

OFFICE USE ONLY
 Log No. 36852
 Permit No. _____
 Basin 8-103
 NOTICE OF INTENT NO. 13371

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER R J Enterprises ADDRESS AT WELL LOCATION R J Enterprises
 MAILING ADDRESS P. O. Box 2086 21 Cash Drive, Mound House, Nevada
Carson City, Nevada 89702
 2. LOCATION NE 1/4 SW 1/4 Sec. 29 T. 16 N. R. 21 E Lyon County
 PERMIT NO. M/O-417 Parcel No. N/A Subdivision Name N/A
Issued by Water Resources

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Yellow Brown Silty Sand Interbedded With Sandy Silt		0.0	12.5	12.5
Light Brown to Olive Brown to Red Brown Clayey Sand Interbedded with Silty Sand	Yes	12.5	20.5	8.0
Olive Brown Sand	Yes	20.5	23.0	2.5
Light Brown Sandy Clay	Yes	23.0	28.5	5.5
Light Brown Silt	Yes	28.5	29.5	1.0
Light Brown Sandy Clay	Yes	29.5	31.5	2.0
Light Brown Sandy Silt	Yes	31.5	32.5	1.0
Light Brown Clayey Sand	Yes	32.5	35.0	

8. WELL CONSTRUCTION
 Depth Drilled 35.0 Feet Depth Cased 35.0 Feet
 HOLE DIAMETER (BIT SIZE)
 From 8.0 Inches To 40.0 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2.0	0.5	Schedule 40	0.0	35.0

Perforations:
 Type perforation Slotted
 Size perforation 0.01 inches
 From 15.0 feet to 30.0 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal 10.0
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 13.0 feet to 35.0 feet

9. WATER LEVEL
 Static water level 27.0 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Pezonella Associates, Inc. Contractor
 Address 520 Edison Way, Reno, Nevada 89502 Contractor
 Nevada contractor's license number C-4186
 issued by the State Contractor's Board
 Nevada driller's license number issued by the M-1629
 Division of Water Resources the on-site driller
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date 7-15-91

Date started May 9, 1991
 Date completed May 10, 1991

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			