

OFFICE USE ONLY
 Log No. 36855
 Permit No. _____
 Basin 103

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 17650

1. OWNER Mortimer Hyett ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 260 Parr B. lvd Space 114 194 Julie Way
Reno, NV 89512 Dayton, NV 89403
 2. LOCATION NE $\frac{1}{4}$ SE $\frac{1}{4}$ Sec. 20 T. 17 S/R 22 E. Storey County
 PERMIT NO. 03-316-06 Mark Twain Estates
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Overburden with small boulders and cobbles		0	12	12
Cemented boulders & gravels, hard		12	90	78
Tight, hard clay with small gravels		90	115	25
Hard, tight sand with clay lenses		115	164	39
Sand with small gravels		164	175	11
Cemented sand and gravel, very hard		175	245	70
Sand and gravels with water	xx	245	297	52
Total depth: 300 feet				
Well capacity: 20 gpm				

8. WELL CONSTRUCTION
 Depth Drilled 300 Feet Depth Cased 300 Feet
 HOLE DIAMETER (BIT SIZE)
 From 0 Feet To 70 Feet
11 3/4 Inches
 From 70 Feet To 300 Feet
8 1/2 Inches
 From _____ Feet To _____ Feet
 _____ Inches

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	2	300

Perforations:
 Type perforation Factory Mill Slots
 Size perforation 3" x 3/32"
 From 280 feet to 300 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 70 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 70 feet to 300 feet

9. WATER LEVEL
 Static water level 168 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature Cool °F Quality Good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name A & H PUMP CO.
 Contractor
 Address 3 Carson City, NV 89701
 Contractor

Date started May 28 1991
 Date completed May 31 1991

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift			
Developed well with air. Blew 20 gpm from 260 for 2 hours until well clear.			

Address 5551 Hiway 50 E., Unit 3
 Nevada contractor's license number issued by the State Contractor's Board 31839
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1674
 Signed Jerry B. Butts
 By driller performing actual drilling on site or contractor
 Date May 31, 1991