WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 36857
Permit No.
Basin 103

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 17014

1. OWNER Clyde Enloe
MAILING ADDRESS PO Box 1345
Dayton NV

ADDRESS AT WELL LOCATION
419 U+T Way
Dayton NV

2. LOCATION SW ¼ SW ¼ Sec 28 T 17 N S R 22 E Lyon County
PERMIT NO. N/A (Issued by Water Resources) 19-262+07 (Parcel No.) MARK TWAIN #4 (Subdivision Name)

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Topsoil		0	6	6
SAND		6	10	4
Brown Sandy Clay	—	10	65	55
Clay w/ stainings	—	65	120	55
Sand + gravel				
Coarse sand/gravel	—	120	127	7
Brown Stick Clay	—	127	130	3

91 JUL 17 AM 11:11
RECEIVED
STATE ENGINEERS OFFICE

Date started June 20, 1991
Date completed June 21, 1991

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
N/A	N/A	N/A	N/A

AIR LIFT ~~BAILER TEST~~

G.P.M. 23 Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION

Diameter 10 5/8 inches Total depth 130 feet
..... inches
..... inches
Casing record 1 ft above to 130'
Weight per foot ..... Thickness .188

Diameter	From	To
6 5/8 inches	0 feet	130 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Cement grout
Depth of seal 52 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 52 feet to 130 feet

Perforations:
Type perforation Factory Milled
Size perforation 3/32
From 90 feet to 130 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL

Static water level 64 feet below land surface
Flow N/A G.P.M. N/A P.S.I.
Water temperature Cold °F Quality clear

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Enloe Drilling (Contractor)
Address PO Box 1345 Dayton (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 4739 A
Nevada contractor's driller's number issued by the Division of Water Resources 249
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 590
Signed [signature] By driller performing actual drilling on site or contractor
Date July 15, 1991

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627