

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 17232

1. OWNER ED CHAVES ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS Box 139 South of Fort Churchill Road
Dayton, Nevada 89403 Dayton, Nevada
 2. LOCATION NE 1/4 SE 1/4 Sec. 30 T. 17 N/S R. 22 E Lyon County
 PERMIT NO. 16-023-01 None
 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Overburden & clays		0	6	6
Medium sized gravels with fine to course sand	xx	6	114	108
Course gravel with course sand	xx	114	140	26
TD: 140 ft				

91 MAY 1991 8853
 STATE ENGINEER

8. WELL CONSTRUCTION
 Depth Drilled 140 Feet Depth Cased 140 Feet
 HOLE DIAMETER (BIT SIZE)
 From 11 3/4 Inches To 0 Feet
1140 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	2	140

Perforations:
 Type perforation Factory Mill Slot
 Size perforation 3" x 3/32"
 From 120 feet to 140 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 100 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 100 feet to 140 feet

9. WATER LEVEL
 Static water level 12 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cool °F Quality good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name A & H PUMP CO.
 Contractor

Date started May 2 1991
 Date completed May 6 1991

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift			
Flushed drill mud from well with clean water, gravel packed and sealed well with neat cement grout through a tremie pipe. Developed well with 250-450 air. Blew in excess of 30 gpm from 110 ft for 2 hours.			

Address 5551 Hiway 50 East, Unit #3
 Contractor
Carson City, NV 89701
 Nevada contractor's license number issued by the State Contractor's Board 31839
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1679
 Signed Joey B. Bell
 By driller performing actual drilling on site or contractor
 Date 5/9/91