

OFFICE USE ONLY
 Log No. 36875
 Permit No. _____
 Basin. B-104

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 17692

1. OWNER GARY JONES ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 613 E Spear 2561 Snyder
Carson City, NV Carson City, NV
 2. LOCATION SE 1/4 SE 1/4 Sec. 10 T. 15 N/S R. 20 E Carson City County
 PERMIT NO. 10-491-08 None
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Overburden, sand		0	5	5
Medium hard to hard granodiorite		5	60	55
Red clay seam, hard		60	66	6
Granodiorite, grey-white, hard, with fractures carrying water, major water between 132-138'	xxx	66	140	74
Total depth: 140 ft				
Well capacity rated at 25-28 gpm from 120 feet with air lift.				

8. WELL CONSTRUCTION
 Depth Drilled 140 Feet Depth Cased 140 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
11 Inches 0 Feet 100 Feet
9 1/2 Inches 100 Feet 140 Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	2	140

Perforations:
 Type perforation Factory mill slots
 Size perforation 3" x 3/32"
 From 120 feet to 140 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 100 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 100 feet to 140 feet

9. WATER LEVEL
 Static water level 62 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cool °F Quality good

Date started June 8 1991
 Date completed June 10 1991

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Developed well with 450-250 air for three hours until well stabilized and cleaned			

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name A & H PUMP CO. Contractor
 Address 5551 hiway 50, unit 3 Contractor
Carson City, NV 89701
 Nevada contractor's license number issued by the State Contractor's Board 31839
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1476
 Signed [Signature] By driller performing actual drilling on site or contractor
 Date 6/10/91