WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 36906
Permit No.
Basin 212

NOTICE OF INTENT NO.

1. OWNER L. William Goldojarb
MAILING ADDRESS 13934 Chandler Blvd., Sherman Oaks, CA 91401
ADDRESS AT WELL LOCATION 3328 Losee Rd., No. Las Vegas, Nv. 89030

2. LOCATION SW ¼ SE ¼ Sec. 11 T. 20 N/S R. 61 E. Clark County
PERMIT NO. M0-2148 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other HSA

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
2" Asphaltic Concrete		0"	2"	2"
Brown clayey sand w/gravel		2"	8'	7'10"
Brown clayey gravel		8'	12'	4'
Brown sand clay		12'	22'	10'
Lt. br. clayey sand		22'	26'	4'
Brwn. sandy clay		26'	31'	5'
Brwn. clayey gravel		31'	34'	3'
Brwn. sandy clay	▼	34'	49'	15'
Brwn. clayey sand		49'	51'	2'
Brwn sandy clay		51'	60'	9'
total depth 60'				

RECEIVED
Div. of Water Resources
Branch Office - Las Vegas, Nv.

Date started 4-23, 1992
Date completed 4-23, 1992

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 60 Feet Depth Cased 30 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
8 Inches	0 Feet	60 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2"	.7 lbs.	Sch. 40 PVC	0	60

Perforations:
Type perforation MACHINE SLOTTED
Size perforation 0.020 INCH
From 30 feet to 60 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 25' + 2' Bentonite
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout ☒ Bentonite

Gravel Packed: ☒ Yes ☐ No
From 27 feet to 60 feet

9. WATER LEVEL
Static water level 43.1 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Richard Le Blanc (Contractor)
Address 4670 S. Polaris Ave. (Contractor)
Las Vegas, Nv.
Nevada contractor's license number issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M1817
Signed (By driller performing actual drilling on site or contractor)
Date 4-27-92

(Rev. 3-91)
USE ADDITIONAL SHEETS IF NECESSARY
(O)-627