

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. **36933**
 Permit No. _____
 Basin. **212**

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. **9493**

1. OWNER **oil field trucking** ADDRESS AT WELL LOCATION **oil field trucking**
 MAILING ADDRESS **c/o Broadbent & Assoc.** **4426 E. CAREY AVE**
833 NEVADA HWY. BOULDER CITY **LAS VEGAS NV**
 2. LOCATION $\frac{1}{4}$ SW $\frac{1}{4}$ Sec. **17** T. **20** N. R. **62 E** **Clark** County
 PERMIT NO. **Mo 2125** Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other **Auger**

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thick-ness |
|---------------------|--------------|------|-----|------------|
| Asphalt/Baserock | | 0 | .75 | .75 |
| Silty Sand | | .75 | 12' | 11.25' |
| Silty Sand w/gravel | | 12' | 18' | 6' |
| Sandy Silt w/clay | | 18' | 22' | 4' |
| Clayey silt | | 22' | 40' | 18' |
| Clayey silt w/sand | | 40' | 65' | 25' |
| T.D. = 65' | | | | |

8. WELL CONSTRUCTION
 Depth Drilled **65** Feet Depth Cased **65** Feet
 HOLE DIAMETER (BIT SIZE)
 From 8 Inches To 0 Feet 65 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|--------------------|---------------------|-------------------------|-------------|-----------|
| 2" | .7 lbs | 0.020 | 0 | 65 |
| | | Scat 40 | | |

Perforations:
 Type perforation **factory slotted**
 Size perforation **0.020**
 From **35** feet to **65** feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal **0-30/28-30 Feet** Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No **w/Berf.**
 From **30** feet to **65** feet

9. WATER LEVEL
 Static water level **55** feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

Date started **2-21** 19**92**
 Date completed **2-21** 19**92**

7. WELL TEST DATA

| TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift | | | |
|--|-------------------------------|--------------|--|
| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) | |
| | | | |
| | | | |
| | | | |
| | | | |

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name **RICHARD LEBLANC** Contractor
 Address **4670 S. POLARIS** Contractor
LAS VEGAS, NV 89103
 Nevada contractor's license number issued by the State Contractor's Board _____
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller **M1817**
 Signed **R. LeBlanc**
 By driller performing actual drilling on site or contractor
 Date **2-25-92**

RECEIVED
MAR 10 1992
 Div. of Water Resources
 Branch Office - Las Vegas, NV