WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 36934 in Book
Permit No.
Basin 212

NOTICE OF INTENT NO. 9494

1. OWNER oil field trucking Co.
MAILING ADDRESS c/o Broadbent Consult. 833 Nevada Hwy, Boulder City
ADDRESS AT WELL LOCATION oil field trucking 4486 E. Carey Ave. Las Vegas, NV.

2. LOCATION ¼ SW ¼ Sec. 17 T. 20 N/S R. 62 E. County Clark
PERMIT NO. M02125 Issued by Water Resources | Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other Auger.

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Asphalt / Baserock		0	.75	.75
Silty Sand w/ gravel & cobbles		.75	5.0	4.25
Sandy silt		5.0	16.0	11.0
Clayey silt w/ Sand		16.0	24.0	8.0
Clayey silt		24.0	40.0	16.0
Clayey silt w/ Sand		40.0	48.0	8.0
Same / no sand		48.0	50.0	2.0
Same w/ Sand		50.0	65.0	15.0
T.D. 65'				

RECEIVED
MAR 10 1992
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started 2-21, 1992
Date completed 2-21, 1992

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 65 Feet Depth Cased 65 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
8 Inches		0 Feet	65 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2"	.71 lbs	Sch. 40	0	65

Perforations:
Type perforation factory slotted
Size perforation 0.020
From 45 feet to 65 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 0-40 / 38-40 Bent.
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☐ Neat Cement ☑ Cement Grout ☐ Concrete Grout w/ Bent.
Gravel Packed: ☑ Yes ☐ No
From 40 feet to 65 feet

9. WATER LEVEL
Static water level 55 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Richard LeBlanc Contractor
Address 4670 S. Valarts Contractor
Las Vegas, NV. 89103
Nevada contractor's license number issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M1817
Signed R. LeBlanc
By driller performing actual drilling on site or contractor
Date 2-25-92

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627