WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 369946
Permit No.
Basin 212

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 9445

1. OWNER PAYLESS INC, 9275 S. Peyton Lane
MAILING ADDRESS ~~550 S.H.L. Sub 1440~~
Wilsonville, OR

ADDRESS AT WELL LOCATION NWC corner of SAHARA AVE + VALLEY VIEW BLVD
LAS VEGAS, NV

2. LOCATION SE ¼ SW ¼ Sec 6 T 21 N/S R 61 E CLARK County
PERMIT NO. MO-2138 Issued by Water Resources | Parcel No. | Subdivision Name

3. TYPE OF WORK: New Well ☒ Recondition ☐ Deepen ☐ Other ☐

4. PROPOSED USE: Domestic ☐ Irrigation ☐ Test ☒ Monitoring Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL: Cable ☐ Rotary ☒ Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
ASPHALT		0	0.5	0.5
ARTIFICAL FILL		0.5	3.5	3.0
SANDY silt w/clay		3.5	7.0	3.5
Silty clay		7.0	11	4.0
Clay w/silt		11	12.5	1.5
CALICHE		12.5	15.0	2.5
Silty clay		15.0	18.5	3.5
gravelly Clay w/silt		18.5	26	7.5
Silty CLAY w/gravels		26	39	13
Silty GRAVELS		39	40	1

Date started MARCH 19, 1992
Date completed MARCH 19, 1992

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

RECEIVED
APR 06 1992
Div. of Water Resources
Branch Office - Las Vegas, NV

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 6" inches Total depth 40 feet
inches
inches
Casing record 0-40
Weight per foot 0.70 Thickness Sch 40

Diameter	From	To
6 inches	0 feet	40 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐, Type grout (cement)
Depth of seal 0-3 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 5 feet to 40 feet

Perforations:
Type perforation Factory slotted
Size perforation 0.010
From 10 feet to 40 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level feet below land surface
Flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Don Wilson / Converse Consultants (Contractor)
Address 4670 S. Polaris Ave LAS VEGAS, NV (Contractor)
Nevada contractor's license number issued by the State Contractor's Board
Nevada contractor's driller's number issued by the Division of Water Resources
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M1589
Signed Don Wilson (By driller performing actual drilling on site or contractor)
Date

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627