WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 369666 In book
Permit No.
Basin 212

NOTICE OF INTENT NO. 9456

1. OWNER CLARK COUNTY SCHOOL DISTRICT
MAILING ADDRESS 1700 GALLERIA, BLDG C
HENDERSON, NV 89014

ADDRESS AT WELL LOCATION R.C. WHITE TRANSPORTATION CENTER, 4499 S. ARVILLE, LAS VEGAS NV, 89103

2. LOCATION SE 1/4 NW 1/4 Sec. 19 T. 21 N/S R. 61 E. CLARK County
PERMIT NO. MO-2144 Issued by Water Resources | Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
PAVEMENT/FILL		0	1	1.0
SANDY GRAVEL		1	3	2.0
BROWN SANDY SILT		3	4	1.0
TAN SANDY SILT		3	8	5.0
CALICHE		8	9	1.0
BROWN SANDY SILT		9	12	3.0
SILTY SAND		12	15	3.0
WHITE SANDY SILT		15	17.5	2.5
CALICHE - DENSE		17.5	23	4.5
BROWN CLAY	▼	23	28	5.0
LT BROWN CLAYEY SILT		28	35	7.0
CLAYEY SILT SAND		35	40	5.0
TOTAL DEPTH 40 FEET				

RECEIVED
MAY 13 1992
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started 04-13, 1992
Date completed 04-13, 1992

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 40 Feet Depth Cased 40 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
8 Inches	0 Feet	40 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2	0.70	0.308 (Sch. 40 PVC)	0	40

Perforations:
Type perforation FACTORY SLOTTED
Size perforation 0.02 INCH
From 10 feet to 40 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 0 - 15.5 / 12.5-15.5 BENTONITE
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 15.5 feet to 40 feet

9. WATER LEVEL
Static water level 22 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature 85 °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name DON WILSON Contractor
Address 4670 S. POLARIS Contractor
LAS VEGAS, NV 89103
Nevada contractor's license number issued by the State Contractor's Board N/A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M 1589
Signed [signature] By driller performing actual drilling on site or contractor
Date

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627