

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 14789

1. OWNER Claudia McIntosh ADDRESS AT WELL LOCATION 7350 Lakeside Drive
 MAILING ADDRESS 7350 Lakeside Drive 7350 Lakeside Drive
Reno, Nev 89511 Reno, Nev 89511

2. LOCATION SW 1/4 NW 1/4 Sec 1 T. 18N N/S R. 18/9 E Washoe County
 PERMIT NO. N/A 040-573-05 Lakeside Meadows Lot #9
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Abandon 8" domestic well and perforate casing from 50' to 90' where a 4" liner was installed. Then pumped neat cement with tremie tube from bottom to top. This procedure was done after discussions with Steve Womley and Tom Gallager.				
break in casing				
Cascading water at approx. 42' deep				
JUN 25 AD 26				
STATE ENGINEERS INC.				
91				
Could not grip casing to attempt pulling liner.				

8. WELL CONSTRUCTION
 Depth Drilled 163' Feet Depth Cased 163' Feet

HOLE DIAMETER (BIT SIZE)
 From _____ To _____
N/A Inches _____ Feet _____
 _____ Inches _____ Feet _____
 _____ Inches _____ Feet _____

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8"		.188	0	90
4" ?			90	163

Perforations:
 Type perforation Mills knife to abandon
 Size perforation _____
 From 50 feet to 90 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal top to bottom Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 45' 2 1/2" feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name MacKay Pump & Geothermal, Inc.
 Address 1600 Mt. Rose Hwy Reno, NV 89511

Date started June 18, 1991
 Date completed June 19, 1991

7. WELL TEST DATA

TEST METHOD: Bailor Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

Nevada contractor's license number issued by the State Contractor's Board 23096
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller M1719
 Signed R. Bruce MacKay
 By driller performing actual drilling on site or contractor
 Date 6-23-'91