

WELL DRILLER'S REPORT

Please complete this form in its entirety

NOTICE OF INTENT NO. 17567

PRINT OR TYPE ONLY

1. OWNER CLAUDIA MACKINTOSH ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 7350 Lakeside Drive Same _____
Reno, NV 89511
 2. LOCATION SW 1/4 NW 1/4 Sec 1 T. 18N N/S R. 19 E Washoe County _____
 PERMIT NO. 040-573-05 Parcel No. _____ SW Reno area Subdivision Name _____
Issued by Water Resources

3. TYPE OF WORK
 New Well & Recondition
 Deepen Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock
 5. TYPE WELL
 Cable Rotary
 Other Air _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Attempt to deepen existing well. Small casing at 90 ft. Can not be deepened.			5-30-91	
NEW WELL:				
Sand & gravels		0	2	2
Sandy brown clay		2	30	28
Soft zone	X	30	38	8
Sandy brown clay		38	89	51
Soft zone	X	89	93	4
Sandy brown clay		93	103	10
Soft zone	X	103	105	2
Brown volcanic rock		105	128	23
Fracture	X	128	129	1
Brown volcanic rock		129	165	36
Fracture	X	165	167	2
Brown volcanic rock		167	188	11
Fracture		188	189	1
Brown volcanic rock		189	222	33
Fracture	X	222	227	5
Brown volcanic rock		227	250	23

8. WELL CONSTRUCTION
 Diameter 8 5/8 inches Total depth 250 feet
10 inches 0 to 100 ft
_____ inches
 Casing record 250' steel casing installed.
 Weight per foot _____ Thickness .188

Diameter	From	To
<u>6 5/8</u> inches	<u>0</u> feet	<u>250</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

 Surface seal: Yes No Type Cement grout
 Depth of seal 100 feet
 Gravel packed: Yes No
 Gravel packed from 100 feet to 250 feet
 Perforations:
 Type perforation factory sawed slot perf.
 Size perforation 3/32 x 3 x 5 around
 From 135 feet to 195 feet
 From _____ feet to _____ feet
 From 215 feet to 235 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Date started 6-3-91, 19____
 Date completed 6-4-91, 19____

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST

G.P.M.	Draw down	feet	hours

9. WATER LEVEL
 Static water level 33 feet below land surface
 Flow 18 G.P.M. _____ P.S.I.
 Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Wayne Drilling, Inc. Contractor
 Address P.O. Box 12370, Reno, NV 89510 Contractor
 Nevada contractor's license number issued by the State Contractor's Board 22549
 Nevada contractor's driller's number issued by the Division of Water Resources 908
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
 Signed Wayne C. Johnson
 By driller performing actual drilling on site or contractor
 Date June 7, 1991