WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 37025
Permit No.
Basin 87

NOTICE OF INTENT NO. 14792

1. OWNER David Pugh
MAILING ADDRESS 7275 Lakeside Drive
Reno, Nev 89511

ADDRESS AT WELL LOCATION
7275 Lakeside Drive
Reno, Nev 89511

2. LOCATION SE ¼ NE ¼ Sec. 2 T 18N N/S R 19 E Washoe County

PERMIT NO. N/A (Issued by Water Resources) | 041-110-60 (Parcel No.) | Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Abandon 8" well and perforate from 0-90' where a 7"? liner was placed to bottom of hole, 230' and abandon per conversation with Steve Womsley and Tom Gallager				
Break in casing, cascading water @ approx. 42' deep				
Could not grip liner to attempt pulling.				

JUN 25 AM 10:26 '91 STATE ENGINEER

Date started June 18, 19 91
Date completed June 19, 19 91

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 230± Feet Depth Cased 230± Feet

HOLE DIAMETER (BIT SIZE)

		From	To
N/A	Inches	Feet	Feet
	Inches	Feet	Feet
	Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 3/4		.250	0	90
7?			90	230

Perforations:
Type perforation Mills Knife
Size perforation
From 0 feet to 90 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☐ No
Depth of Seal
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☐ Yes ☐ No
From feet to feet

9. WATER LEVEL
Static water level 177'4" feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name MacKay Pump & Geothermal, Inc. (Contractor)
Address 1600 Mt. Rose Hwy (Contractor)
Reno, Nev 89511
Nevada contractor's license number issued by the State Contractor's Board 23096
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M1719
Signed R. Bruce MacKay (By driller performing actual drilling on site or contractor)
Date 6-23-'91

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627