

WELL DRILLER'S REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 17564

1. OWNER DAVID PUGH ADDRESS AT WELL LOCATION Same
 MAILING ADDRESS 7275 Lakeside Drive
Reno, NV 89511
 2. LOCATION NE 1/4 NW 1/4 Sec 2 T. 18N N/S R. 19E E Washoe County
 PERMIT NO. 41-110-60 SW Reno
 Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK
 New Well Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock

5. TYPE WELL
 Cable Rotary
 Other Air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top soil		0	3	3
Brown clay with gravels & sand & boulders		3	40	37
Brown volcanic rock - broken		40	71	31
GRay volcanic rock		71	128	57
Light bron volcanic rock		128	160	32
GRay volcanic rock		160	203	43
BRown volcanic rock		203	256	53
Gray volcanic rock		256	270	14
FRacture	X	270	271	1
GRay volcanic rock		271	283	12
FRacture	X	283	285	2
GRay volcanic rock		285	300	15

91 JUN -4 10:36 STATE ENGINEERS DIVISION

8. WELL CONSTRUCTION
 Diameter 8 5/8 inches Total depth 300 feet
10 inches 0 to 50 ft.
_____ inches
 Casing record 300' steel casing installed.
 Weight per foot _____ Thickness 188

Diameter	From	To
<u>6 5/8</u> inches	<u>0</u> feet	<u>300</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

 Surface seal: Yes No Type cement grout
 Depth of seal 100 feet
 Gravel packed: Yes No
 Gravel packed from 100 feet to 300 feet
 Perforations:
 Type perforation factory sawed slot
 Size perforation 3/32 x 3 x 5 around
 From 252 feet to 292 feet
 From _____ feet to _____ feet

Date started 5-28-91, 19____
 Date completed 5-29-91, 19____

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST

G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours

9. WATER LEVEL
 Static water level 180 feet below land surface
 Flow 27 1/2 100 G.P.M. _____ P.S.I.
 Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Wayne Drilling, Inc.
 Address P.O. Box 12370, Reno, NV 89510
 Nevada contractor's license number 22549
 issued by the State Contractor's Board
 Nevada contractor's driller's number 908
 issued by the Division of Water Resources
 Nevada driller's license number issued by the 923
 Division of Water Resources, the on-site driller.
 Signed Wayne Drilling, Inc.
 By driller performing actual drilling on site or contractor
 Date May 31, 1991