WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 37026
Permit No.
Basin 87

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 54087

1. OWNER Dave Youngker
MAILING ADDRESS 340 Sierra Manor Reno NV
ADDRESS AT WELL LOCATION 340 Sierra Manor Reno NV

2. LOCATION SE ¼ NE ¼ Sec. 7 T. 18 N/S R. 20 E. Washoe County
PERMIT NO. ____ Issued by Water Resources
Parcel No. 024-387-02
Subdivision Name ~~[illegible]~~

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐ Mud Rotary

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Brown top soil | | 0 | 12 | 12 |
| Sandy clay | | 12 | 46 | 34 |
| Gravel and sand mix | | 46 | 155 | 109 |

'91 JUN 19 P2:18
STATE ENGINEER'S OFFICE

Date started June 7, 19 91
Date completed June 10, 19 91

7. WELL TEST DATA

| Pump RPM | G.P.M. | Draw Down | After Hours Pump |
|---|---|---|---|
| | | | |

BAILER TEST
G.P.M. ____ Draw down ____ feet ____ hours
G.P.M. ____ Draw down ____ feet ____ hours
G.P.M. ____ Draw down ____ feet ____ hours

8. WELL CONSTRUCTION
Diameter hole 12 inches Total depth 155 feet
Casing record 155
Weight per foot 11 Thickness 188

| Diameter | From | To |
|---|---|---|
| 6 5/8 inches | 0 feet | 155 feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |

Surface seal: Yes ☒ No ☐ Type Cement
Depth of seal 100 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 100 feet to 155 feet

Perforations:
Type perforation Mill slot
Size perforation 3 3/32
From 135 feet to 155 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

9. WATER LEVEL
Static water level 24 feet below land surface
Flow 60 G.P.M. ____ P.S.I.
Water temperature Cool ° F. Quality unknown

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Castle Drilling Co. (Contractor)
Address 12000 S. Virginia Reno 89511 (Contractor)
Nevada contractor's license number 27767
Nevada contractor's drillers number 1600
Nevada driller's license number 1287 (Actual Driller)
Signed [signature] (Contractor)
Date 6-18-91

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 6-81) O-627 CR434