

OFFICE USE ONLY
 Log No. 37053
 Permit No. _____
 Basin 89

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 17648

1. OWNER Bailey Construction ADDRESS AT WELL LOCATION Lot 20-A
 MAILING ADDRESS 2117 Thomas Jefferson 215 Jackdaw Lane
Reno, NV 89509 Carson City, NV 89704
 2. LOCATION SE 1/4 SE 1/4 Sec 31 T 17 N S R 20 E Washoe County
 PERMIT NO. 50-419-01 New Washoe City # 6
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Overburden and sand		0	15	15
Fine to course sand		15	130	115
Medium to course gravels with sand, carrying water	xx	130	140	10
Well capability: 15 gpm from 100 ft				
TD: 140 ft				

8. WELL CONSTRUCTION
 Depth Drilled 140 Feet Depth Cased 140 Feet
 HOLE DIAMETER (BIT SIZE)
 From 11 1/2 Inches To 140 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 7/8	13.03	.188	2	140

Perforations:
 Type perforation Factory Mill Slotted
 Size perforation 3" x 3/32"
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 70 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 70 feet to 140 feet

Date started May 16, 1991
 Date completed May 20, 1991

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Flushed drill mud from well and gravel packed annulus. Developed well with air. Blew 15 gpm from 100 ft for three hours until clean.		

9. WATER LEVEL
 Static water level 60 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cool °F Quality good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name A & H PUMP CO.
 Address 5551 Highway 50 E, #3 Carson City, NV 89701
 Contractor
 Nevada contractor's license number issued by the State Contractor's Board 31839
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1674
 Signed [Signature]
 By driller performing actual drilling on-site or contractor
 Date May 20, 1991