WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 37066
Permit No.
Basin 101

NOTICE OF INTENT NO. 17088

1. OWNER RON WARD
MAILING ADDRESS 2805 SCHURZ HWY
FALLON, NV 89406
ADDRESS AT WELL LOCATION 2805 SCHURZ HWY
FALLON, NV 89406

2. LOCATION NW ¼ SW ¼ Sec. 6 T. 18 N/S R. 29 E CHURCHILL County
PERMIT NO. NA (Issued by Water Resources) 006-731-05 (Parcel No.) NA (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
CLAY		0	4	4
SAND		4	8	4
CLAY		8	10	2
SAND		10	23	13
CLAY		23	29	6
BLACK CLAY & SILT		29	61	32
GRAY CLAY & SAND		61	92	31
COARSE SAND & GRAVEL	X	92	111	19
WITH CLAY STREAKS				

'91 JUN 10 A0:16 STATE ENGINEER'S OFFICE

Date started 6-7-91, 19
Date completed 6-7-91, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
AIR BLOWN @ 40 GPM		

8. WELL CONSTRUCTION
Depth Drilled 111 Feet Depth Cased 111 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 Inches	0 Feet	50 Feet
6 1/8 Inches	50 Feet	111 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.9	.188	0	111

Perforations:
Type perforation MACHINE SLOT
Size perforation 3/32 X 3
From 104 feet to 109 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☐ Yes ☒ No
From feet to feet

9. WATER LEVEL
Static water level 10 feet below land surface
Artesian flow NA G.P.M. NA P.S.I.
Water temperature 58 °F Quality NA

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WELSCO CORP. (Contractor)
Address P. O. BOX 888 (Contractor)
FALLON, NV 89406
Nevada contractor's license number issued by the State Contractor's Board 11752
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 772
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 6-7-91

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627