

OFFICE USE ONLY
 Log No. **37084**
 Permit No. _____
 Basin. **212**

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. **11148**

1. OWNER **ANDERSON DAIRY** ADDRESS AT WELL LOCATION **ANDERSON DAIRY**
 MAILING ADDRESS **C/O Broadbent & Assoc. 801 SEARLES AVE**
833 NEVADA HWY, BOULDER CITY LAS VEGAS, NEVADA
 2. LOCATION $\frac{1}{4}$ NW $\frac{1}{4}$ Sec **26** T. **20** N. R. **61** E. **CLARK** County
 PERMIT NO. **Mo 2152** Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other **Auger**

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Silty Sand w/ gravel & cobbles		0	5	5
Sandy silt w/ gravel		5	11	6
Sandy silt w/ gravel 90% decreasing		11	16	5
losing gravel & gaining clay		16	25	9
T.D. = 25'				

8. WELL CONSTRUCTION

Depth Drilled **25** Feet Depth Cased **25** Feet

HOLE DIAMETER (BIT SIZE)

Inches	From	To	Feet	Feet
8	0	25		

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2"	Sch. 40	7/8"	0	25

Perforations:
 Type perforation **Factory slotted**
 Size perforation **0.020**
 From **10** feet to **25** feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal **0.7' / Bet. 5.7'** Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
w/ bet.

Gravel Packed: Yes No
 From **7** feet to **25** feet

RECEIVED

JUN 2 1992

Div. of Water Resources
 Branch Office - Las Vegas, NV

Date started **5.6**, 19**92**
 Date completed **5.6**, 19**92**

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

9. WATER LEVEL
 Static water level **15** feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name **RICHARD LEDBETTER** Contractor
 Address **4670 S. SOLARIS AVE**
LAS VEGAS, NEVADA 89103
 Nevada contractor's license number issued by the State Contractor's Board _____
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller **M1817**
 Signed **[Signature]**
 By driller-performing actual drilling on site or contractor
 Date **5.11.92**