

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 37093
 Permit No. _____
 Basin 212

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 11218
2625 W Sahara Ave.

1. OWNER The Southland Corp. ADDRESS AT WELL LOCATION 2625 W Sahara Ave.
 MAILING ADDRESS 2167 S. Alton way,
Englewood, CO 80112 Las Vegas, NV

2. LOCATION NE 1/4 NE 1/4 Sec 8 T 21 N R 61 E Clark County
 PERMIT NO. Waiver m/o-539 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sandy Gravel	N	0-5	2-0	1-5
Clayey Sand	N	2-0	2-5	0-5
Sandy Clay	N	2-5	3-0	0-5
Gravelly Clay	N	3-0	5-5	2-5
Silty Clay w/ gravel	N	5-5	8-0	2-5
Sand	N	8-0	8-5	0-5
Silty Clay	N	8-5	10-5	2-0
Silty Clay w/ gravel	N	10-5	11-5	1-0
unconsolidated Caliche	N	11-5	12-0	0-5
consolidated Caliche	N	12-0	14-0	2-0
Clay	Y	14-0	?	?

8. WELL CONSTRUCTION
 Depth Drilled 17 Feet Depth Cased 17 Feet
 HOLE DIAMETER (BIT SIZE)
 From 7 3/8 Inches To 17 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>4</u>		<u>Sch. 40</u>	<u>0</u>	<u>17</u>

Perforations:
 Type perforation Slotted Screen
 Size perforation 0.020 inch
 From 17 feet to 7 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 5 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 17 feet to 6 feet

9. WATER LEVEL
 Static water level 10-5 feet below land surface
 Artesian flow _____ G.P.M. U.P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name WT Environmental Consultants Contractor
 Address 3611 W Tompkins Ave, Contractor
Las Vegas, NV 89103
 Nevada contractor's license number issued by the State Contractor's Board _____
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller M1761
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date 4/20/92

Date started 4/17, 1992
 Date completed 4/17, 1992

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

92 APR 27 AM 1:00
 RECEIVED
 STATE ENGINEERS OF NV

RECEIVED
 MAY 21 1992
 Div. of Water Resources
 Branch Office - Las Vegas

