


OFFICE USE ONLY  
 Log No. 37094  
 Permit No. 212  
 Basin 212



PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 11226

1. OWNER The Southland Corp. ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS 7167 S. Anton way  
Englewood, CO 80112

2. LOCATION Sw 1/4 Sw 1/4 Sec. 6 T 21 N 62 E Clark County  
 PERMIT NO. Waiver 170-537 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other Auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Asphalt	N	0	0.5	0.5
Sandy-Gravel: Fill	N	0.5	1.0	0.5
Sandy Clay	N	1.0	3.0	2.0
Gypsiferous, Sandy Clay	N	3.0	5.5	2.5
Sandy Silt	Y	5.5	6.0	0.5
Sandy Clay	Y	6.0	?	?

8. WELL CONSTRUCTION  
 Depth Drilled 13 Feet Depth Cased 13 Feet

HOLE DIAMETER (BIT SIZE)  
 From 6 1/2 Inches To 0 Feet 13 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>4</u>		<u>Sch 40</u>	<u>0</u>	<u>13</u>

Perforations:  
 Type perforation Slotted Screen  
 Size perforation 0.020 inch  
 From 13 feet to 3 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout

Depth of Seal 1

Placement Method:  Pumped  Poured

Gravel Packed:  Yes  No  
 From 13 feet to 2 feet

RECEIVED

MAY 05 1992

Div. of Water Resources  
 Branch Office - Las Vegas, NV

Date started 4/27, 1992  
 Date completed 4/27, 1992

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

9. WATER LEVEL  
 Static water level 5.5 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name WT Environmental Consultants  
 Address 3611 W Tompkins Ave  
Las Vegas, NV 89103  
 Nevada contractor's license number issued by the State Contractor's Board \_\_\_\_\_  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller M1761  
 Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Date 4/28/92