

OFFICE USE ONLY
 Log No. 37120
 Permit No. _____
 Basin Q4B

WELL DRILLER'S REPORT

Please complete this form in its entirety

NOTICE OF INTENT NO. 3 best?

PRINT OR TYPE ONLY

1. OWNER ROMEZ, William ADDRESS AT WELL LOCATION None
 MAILING ADDRESS 1376 College Ave
Elko, NV 89801
 2. LOCATION SE 1/4 SE 1/4 Sec. 16 T. 23 N/S R. 57 E. ELKO County
 PERMIT NO. 06-52E-01 Parcel No. None Subdivision Name

3. TYPE OF WORK
 New Well Recondition
 Deepen Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock Other
 5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Soil-Sandy loam		0	3	3
Sandy clay		3	28	25
Sand	v v v	28	37	9
Sandy clay (soft)	v	37	45	8
Soft sandy clay		45	98	53
Sand	r	98	99	1
Sandy clay		99	105	6
Sandy clay w/water	89 ft	105	128	23
Sandy clay		128	142	14
Sand	20 ft	142	148	6
Clay		148	151	3
	T.D	151		

8. WELL CONSTRUCTION 151
 Diameter 10 inches Total depth 151 feet
8 inches
6 inches
 Casing record 152 1/2 feet new steel
 Weight per foot 12.92 Thickness .188

Diameter	From	To
<u>6 5/8</u> inches	<u>+ 1 1/2</u> feet	<u>150 1/2</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

 Surface seal: Yes No Type Neat cement
 Depth of seal 50 ft feet
 Gravel packed: Yes No
 Gravel packed from 50 feet to T.D. feet
 Perforations:
 Type perforation Torch cut
 Size perforation 4/16 x 4"
 From 117 feet to 147 feet
 From 85 feet to 100 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Date started 8-9, 1991
 Date completed 8-19, 1991

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
 G.P.M. 20 Draw down 20 feet 2 hours
 G.P.M. 30 Draw down 30 feet 1 hours
 G.P.M. _____ Draw down _____ feet _____ hours

9. WATER LEVEL
 Static water level 68 feet below land surface
 Flow _____ G.P.M. _____ P.S.I.
 Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name MUTH DRILLING Co. Contractor
 Address 203 Pine St., Elko, NV 89801 Contractor
 Nevada contractor's license number issued by the State Contractor's Board 10819
 Nevada contractor's driller's number issued by the Division of Water Resources 632
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 632
 Signed James P. Muth
 By driller performing actual drilling on site or contractor
 Date 8/21/91