WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY
Log No. 37146
Permit No. 55130
Basin 469
Intent # 8893

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER Leslie Stewart ADDRESS 96 Ranch Paradise Valley NV 89424

2. LOCATION SE ¼ NW ¼ Sec. 29 T. 41 N N/S R. 40 E. County
PERMIT NO. 55130

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☐ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☑

5. TYPE WELL
Cable ☑ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0'	2'	2'
Hard pan		2'	5'	3'
Gravel/Strks clay		5'	18'	13'
Clay		18'	20'	2'
Gravel	20'	20'	23'	3'
Rock		23'	31'	8'
Clay and Gravel		31'	52'	21'
Heaving Gravel	52'	52'	100'	48'

Date started Aug 2, 19 91
Date completed Aug 9, 19 91

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. 30+ Draw down 35 feet 2 hours
G.P.M. Draw down 14 feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 8 inches Total depth 100 feet
Casing record Set to bottom
Weight per foot Thickness .188

Diameter	From	To
8 inches	0 feet	100 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type cement
Depth of seal 50 feet
Gravel packed: Yes ☐ No ☑
Gravel packed from feet to feet

Perforations:
Type perforation saw slot
Size perforation ⅛ X 2"
From 60 feet to 100 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 21 Feet below land surface 20'
Flow G.P.M.
Water temperature cool ° F. Quality good

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Mike McNinch
Address 7715 #C McNinch Rd
Nevada contractor's license number 5437
Nevada driller's license number 1712
Signed Mike McNinch
Date 8/9/91
Intent card # 8893

USE ADDITIONAL SHEETS IF NECESSARY

5471

SEP 13 A11:03 STATE ENGINEER'S OFFICE