

OFFICE USE ONLY
 Log No. 37150
 Permit No. DB7 TRUCKEE MEADOWS
 Basin TRUCKEE MEADOWS
 1719

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 1719

1. OWNER CITY OF SPARKS ADDRESS AT WELL LOCATION EASTLAND HILLS
 MAILING ADDRESS P. O. BOX 857 UNIT #2 SUB MAP # 1696 WASHOE CO
SPARKS, NV 89432-0857 FILE # 503150

2. LOCATION NE 1/4 NW 1/4 Sec. 35 T. 20 N. R. 20 E. WASHOE County
 PERMIT NO. 56455 T 503150 UNIT #2 SUB MAP 1696
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
BROWN CLAY W/ BOULDERS		0	28	28
BROWN CLAY W/ BLACK GRVL		28	48	20
BROWN CLAY		48	52	4
BROWN CLAY W/ANGULAR BLK GRVL		52	160	108
BROWN CLAY BLK GRVL BOULDERS		160	173	13
BLUE CLAY W/ GRAVEL		173	180	7
DECOMP GRANITE/BLU CLY/GRVL		180	252	72
GREY CLAY W GRANITE GRVL		252	356	154
DK SHALE MIL W/ SFT STREAKS		356	372	16
BLK SHALEY ROCK		372	378	6
BLACK & GRAY ROCK W/ GRY SHALE		378	400	22
Plugged under NDI 61176				
N 39.563676				
W 119.709163 NAD 87				
A11:31				
SEP 30				

8. WELL CONSTRUCTION
 Depth Drilled 400 Feet Depth Cased 400 Feet

HOLE DIAMETER (BIT SIZE)
 From To
14" Inches 0 Feet 400 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	22	.250	0	400

Perforations:
 Type perforation MILL STOP
 Size perforation 3/32 X 3
 From 60 feet to 400 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 50 feet to 400 feet

9. WATER LEVEL
 Static water level 54 feet below land surface
 Artesian flow NA G.P.M. NA P.S.I.
 Water temperature 52 °F Quality UNSID

Date started 8-13-91, 19____
 Date completed 8-31-91, 19____

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
AIR BLOW @	250 G.P.M.		

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name WEISCO CORP. Contractor
 Address P. O. BOX 888 Contractor
FALCON, NV 89406
 Nevada contractor's license number issued by the State Contractor's Board 11752
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 772
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date 9-27-91