

OFFICE USE ONLY
 Log No. 37151
 Permit No. _____
 Basin D92-A
 NOTICE OF INTENT NO. 17825

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER Rod Feldesman ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 11455 Vicksburg Rd 11455 Vicksburg Rd
Reno, Nv 89506 Lot 14

2. LOCATION NW 1/4 NW 1/4 Sec. 24 T. 21 N/S R. 18 E Washoe County
 PERMIT NO. 86-224-04 Washoe Ranches Unit # 4
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other Air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Rock fragments		157	158	1
D.G. with brown clay layers scattered throughout		158	253	95
T.D. 253 ft				
There is a 20 foot blank on bottom of screen to aid in development and act as cellar				

8. WELL CONSTRUCTION
 Depth Drilled 253 Feet Depth Cased 253 Feet

HOLE DIAMETER (BIT SIZE)
 From 6 1/2 Inches To 253 Feet
 _____ Inches _____ Feet
 _____ Inches _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
5	9.66	.188	143	253

Perforations:
 Type perforation Johnson - Screen
 Size perforation .010
 From 223 feet to 233 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal refer to original log Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 80 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

Date started 8/21/91, 19____
 Date completed 8/21/91, 19____

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>20+</u>		<u>2 hours</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Aqua Drilling & Well Service, Inc
 Contractor
 Address 625 Spice Islands Dr Suite L
Sparks, Nv 89431
 Contractor

Nevada contractor's license number 15291
 issued by the State Contractor's Board

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1132

Signed Roger M. Thrall
 By driller performing actual drilling on site or contractor
 Date Roger M. Thrall 8/22/91