WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 37158
Permit No.
Basin Q92-A

NOTICE OF INTENT NO. 17996

1. OWNER BOB ARNDT
MAILING ADDRESS 11405 Vicksburg
Reno, NV 89506

ADDRESS AT WELL LOCATION 11355 Cimarron
Reno, NV 89506

2. LOCATION NE ¼ SW ¼ Sec. 24 T 21N N/S R 18 E Washoe County
PERMIT NO. (Issued by Water Resources) 86-203-01 (Parcel No.) Silver Knolls (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	3	3
Brown clay		3	16	13
Green clay		16	31	15
Brown sandy clay		31	60	29
Brown clay		60	111	51
Light brown clay		111	161	50
Brown clay		161	198	37
Soft zone	X	198	206	8
Brown clay		206	215	9
Soft zone	X	215	230	15
BRown clay		230	235	5

'91 SEP -3 AM 11:26
STATE ENGINEER

Date started 8-26-91, 19
Date completed 8-27-91, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 235 Feet Depth Cased 235 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 Inches	0 Feet	50 Feet
8 5/8 Inches	50 Feet	235 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	235

Perforations:
Type perforation factory sawed slot
Size perforation 3/32 x 3 x 5 around
From 190 feet to 230 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 235 feet

9. WATER LEVEL
Static water level 174 feet below land surface
Artesian flow 25 G.P.M. P.S.I.
Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Wayne Drillling, Inc. (Contractor)
Address P.O. Box 12370, Reno, NV 89510 (Contractor)

Nevada contractor's license number issued by the State Contractor's Board 22549
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923

Signed Edward F. Arnhoger (By driller performing actual drilling on site or contractor)
Date August 29, 1991

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627