WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 37155
Permit No.
Basin 092-A

NOTICE OF INTENT NO. 18242

1. OWNER: Ernie Lane Guaranteed Drywall
MAILING ADDRESS: 1235 Coney Islands, Sparks, Nv 89431
ADDRESS AT WELL LOCATION: 10890 Osage, Lot 19 Block 2

2. LOCATION: SW ¼ NE ¼ Sec. 25 T. 21 N/S R. 18 E. Washoe County
PERMIT NO. (Issued by Water Resources) — Parcel No. 086-191-01 — Subdivision Name: Silver Knolls Ranches Estates Unit #3

3. WORK PERFORMED: [X] New Well [ ] Replace [ ] Recondition [ ] Deepen [ ] Abandon [ ] Other
4. PROPOSED USE: [X] Domestic [ ] Irrigation [ ] Test [ ] Municipal/Industrial [ ] Monitor [ ] Stock
5. WELL TYPE: [ ] Cable [XX] Rotary [ ] RVC [ ] Air [ ] Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Overburden		0	4	4
Sand & Brown clay		4	21	17
Brown clay & sand with green clay		21	52	31
Brown clay & sand		52	65	13
Sand with brown clay		65	74	9
Brown clay with some sand - multi-colored		74	113	49
Coarse sands multi colored with some brown clay at the bottom	X	113	140	27
There is a 20 foot blank on the bottom of the screen to aid in development.				
T.D. 140 feet				

Date started 8/14/91, 19
Date completed 8/14/91, 19

7. WELL TEST DATA

TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
25		1

8. WELL CONSTRUCTION

Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
11 Inches	0 Feet	55 Feet
8 3/4 Inches	55 Feet	140 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	+1	140

Perforations:
Type perforation: Johnson - Screen
Size perforation: .030
From 110 feet to 120 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [XX] Yes [ ] No
Depth of Seal 50
Placement Method: [X] Pumped [ ] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 140 feet

9. WATER LEVEL

Static water level 70 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cold °F Quality

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name (Contractor): Aqua Drilling & Well Service, Inc
Address (Contractor): 625 Spice Islands Dr Suite L, Sparks, Nv 89431
Nevada contractor's license number issued by the State Contractor's Board: 15291
Nevada driller's license number issued by the Division of Water Resources, the on-site driller: 1132
Signed: Roger M. Thrall (By driller performing actual drilling on site or contractor)
Date: Roger M. Thrall 8/15/91

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627