WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 37163
Permit No.
Basin 44

NOTICE OF INTENT NO. 18081

1. OWNER Robert Galloway
MAILING ADDRESS P.O. Box 5278
Elko, NV 89802

ADDRESS AT WELL LOCATION SW corner of Truckee and 4th

2. LOCATION SE ¼ NW ¼ Sec 27 T 36 N/S R 57 E Elko County

PERMIT NO. (Issued by Water Resources) | 24-051-01-3 (Parcel No.) | Lot 1 Blk 51 River Valley Ranchos (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [X] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Sand | | 0 | 18 | 18 |
| Gravel | | 18 | 20 | 2 |
| Sand & clay | | 20 | 60 | 40 |
| Sand & gravel | X | 60 | 100 | 40 |

91 AUG -1 AM 1:29
STATE ENGINEER'S OFFICE

Date started July 23, 1991
Date completed July 25, 1991

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

| | G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|---|
| Est | 40 | | |

8. WELL CONSTRUCTION
Depth Drilled 100 Feet Depth Cased 100 Feet

HOLE DIAMETER (BIT SIZE)

| | | From | To |
|---|---|---|---|
| 10 5/8 Inches | | 0 Feet | 100 Feet |
| Inches | | Feet | Feet |
| Inches | | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 6 5/8 | | .250 | +1 | 100 |
| | | | | |

Perforations:
Type perforation Torch cut
Size perforation 1/4 x 6
From 70 feet to 100 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [X] Pumped [X] Poured

Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 100 feet

9. WATER LEVEL
Static water level 10 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name HACKWORTH DRILLING, INC. (Contractor)
Address P.O. Box 850 (Contractor)
Elko, NV 89801

Nevada contractor's license number issued by the State Contractor's Board 020582

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1689

Signed David Hewch
By driller performing actual drilling on site or contractor

Date 7-30-1991

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627