

**WELL DRILLER'S REPORT**

Please complete this form in its entirety

NOTICE OF INTENT NO. 15308

PRINT OR TYPE ONLY

1. OWNER David F. Lino 2151 ADDRESS AT WELL LOCATION Flora STREET  
MAILING ADDRESS pinon Rd # 301 Elko

2. LOCATION SE 1/4 SE 1/4 Sec. 12 T. 34 (N)S R. 55 (B) ELKO County  
PERMIT NO. \_\_\_\_\_ Lot 10 BIK C Subdivision Name LAST CHANCE UNIT NO 3 File NO 2902

3. TYPE OF WORK  
New Well  Recondition   
Deepen  Other   
4. PROPOSED USE  
Domestic  Irrigation  Test   
Municipal  Industrial  Stock  Other   
5. TYPE WELL  
Cable  Rotary   
Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Loam		0	10	10
SAND <del>CLAY</del> STONE		10	14	4
CLAY		14	80	66
HARD PAN		80	89	9
CLAY		89	100	11
SAND STONE		100	110	10
SOFT CLAY		110	121	11
SAND STONE & CLAY		121	140	19
SOFT CLAY		140	216	76
SAND STONE	water	216	218	2
SOFT CLAY		218	240	22
SAND STONE	water	240	241	1
SOFT CLAY		241	248	7
HARD CLAY		248	264	16
SAND STONE	water	264	265	1
HARD CLAY		265	285	20
SAND STONE	water	285	290	

8. WELL CONSTRUCTION  
Diameter 10 inches Total depth 290 feet  
Casing record STEEL  
Weight per foot \_\_\_\_\_ Thickness 188  
Diameter \_\_\_\_\_ From \_\_\_\_\_ To \_\_\_\_\_ feet  
6 inches + 2 feet 290 feet  
Surface seal: Yes  No  Type CEMENT  
Depth of seal 65 feet  
Gravel packed: Yes  No   
Gravel packed from 65 feet to 290 feet  
Perforations:  
Type perforation Slots  
Size perforation 3/16 - 3"  
From 256 feet to 290 feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Date started 6-21- 1991  
Date completed 7-3- 1991

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
<u>Blow Test</u>	<u>45</u>		

BAILER TEST  
G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours

9. WATER LEVEL  
Static water level 145 feet below land surface  
Flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
Water temperature 6 °F Quality Good

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name Fertig Drilling Co Contractor  
Address po. Box 525 ELKO NV Contractor  
Nevada contractor's license number issued by the State Contractor's Board 31904  
Nevada contractor's driller's number issued by the Division of Water Resources \_\_\_\_\_  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1854  
Signed Paul C Fertig By driller performing actual drilling on site or contractor  
Date 7-9-91